OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

E. M. Trout Es
Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 10/06/2026 from 2109 East Prospect, Ponca City, OK 74604.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3810-15	1	1	Gymnasium	WC	Elkay	Water fountain	<1 ppb	2.11 ppb	10/06/2026 06:30	Remediation Recommended	
2	3810-17	1	1	Classroom 17	DW		Water fountain to the right of the sink	1.63 ppb	<1 ppb	10/06/2026 06:30	Remediation Recommended	
3	3810-1	1	1	Classroom 18	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
4	3810-2	1	1	Classroom 15	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
5	3810-3	1	1	Classroom 19	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
6	3810-4	1	1	Classroom 14	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
7	3810-5	1	1	Cafeteria	WC	Elkay	Water fountain to the left	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
8	3810-6	1	1	Cafeteria	WC	Elkay	Water fountain in the center	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
9	3810-7	1	1	Cafeteria	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
10	3810-8	1	1	To the right of Classroom 10	WC	Elkay	Bottle Filler to the right	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
11	3810-9	1	1	To the right of Classroom 10	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
12	3810-10	1	1	Across classroom 3	WC	Elkay	Water fountain to the left	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
13	3810-11	1	1	Across classroom 3	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
14	3810-12	1	1	Teacher's Lounge	KF		Sink	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
15	3810-13	1	1	Across Gym	WC	Elkay	Water fountain to the left	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
16	3810-14	1	1	Across Gym	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	
17	3810-16	1	1	Classroom 16	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	10/06/2026 06:30	No Further Action	