OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Woodlands Es
Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 10/06/2026 from 2005 East Woodland Road, Ponca City, OK 74604.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3811-7	1	1	Classroom 7	DW		Water fountain	1.17 ppb	<1 ppb	10/06/2026 05:30	Remediation Recommended	
2	3811-1	1	1	Across the gym	WC	Elkay	Water fountain	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
3	3811-2	1	1	Gymnasium	WC	Elkay	Water fountain	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
4	3811-3	1	1	Teacher's Lounge	KF		Sink in the back	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
5	3811-4	1	1	Across the main office	WC	Elkay	Water fountain	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
6	3811-5	1	1	Across Classroom 7	WC	Elkay	Water fountain to the left	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
7	3811-6	1	1	Across Classroom 7	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
8	3811-8	1	1	Next to Classroom 8	WC	Elkay	Water fountain	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
9	3811-9	1	1	To the right of Classroom 10	WC	Elkay	Water fountain	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
10	3811-10	1	1	Cafeteria	WC	Elkay	Water fountain to the left	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
11	3811-11	1	1	Cafeteria	WC	Elkay	Water fountain in the center	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	
12	3811-12	1	1	Cafeteria	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	10/06/2026 05:30	No Further Action	