OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Ponca City Hs
Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 10/02/2026 from 927 North Fifth, Ponca City, OK 74601.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3815-45	5	1	MSB Bld - Across Room 104	WC	Elkay - ezH20	Water fountain	4.65 ppb	2.97 ppb	10/02/2026 05:30	Remediation Recommended	
2	3815-44	5	1	MSB Bld - Across Room 104	WC	Elkay - ezH20	Bottle Filler	4.49 ppb	3.39 ppb	10/02/2026 05:30	Remediation Recommended	
3	3815-82	7	2	Concert Hall - To the right of the elevator	WC	Elkay - ezH20	WF to the left	1.46 ppb	<1 ppb	10/02/2026 05:30	Remediation Recommended	
4	3815-38	4	2	STEM Academy - Across Nutrition's Office	WC	Elkay	WF in the hallway	<1 ppb	1.26 ppb	10/02/2026 05:30	Remediation Recommended	
5	3815-1	3	1	Allen Robson Fieldhouse- Concessions	IM	Manitowoc	IM	<1 ppb		10/02/2026 05:30	No Further Action	
6	3815-2	3	1	Allen Robson Fieldhouse- Conference Lounge	KF		KF	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
7	3815-3	3	1	Allen Robson Fieldhouse- Across to the family restrooms, near basketball court	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
8	3815-4	3	1	Allen Robson Fieldhouse- Across to the family restrooms, near basketball court	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
9	3815-5	3	1	Allen Robson Fieldhouse- Boy's locker room	WC	Elkay - ezH20	WF	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
10	3815-6	3	1	Allen Robson Fieldhouse- Dressing Room 2	DW	Elkay - ezH20	WF to the left of wrestiling room	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
11	3815-7	3	1	Allen Robson Fieldhouse- Across the elevator machine room	WC	Elkay - ezH20	WF to the left, of wrestling room	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
12	3815-8	3	1	Allen Robson Fieldhouse- Across the elevator machine room	WC	Elkay - ezH20	WF to the right, of wrestiling room	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
13	3815-9	2	1	Football Stadium- Across football coaches locker room	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
14	3815-10	2	1	Football Stadium- Across football coaches locker room	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
15	3815-11	2	1	Football Stadium- Across room 114	WC	Elkay - ezH20	WF to the left - filter status red	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
16	3815-12	2	1	Football Stadium- Across room 114	WC	Elkay - ezH20	Bottle Filler - filter status red	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
17	3815-13	2	1	Football Stadium- Across room 114	WC	Elkay - ezH20	WF to the right - filter status red	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
18	3815-14	2	1	Football Stadium- Room 106	IM	Scotsman	IM	<1 ppb		10/02/2026 05:30	No Further Action	
19	3815-15	2	1	Football Stadium- Concessions (On the track)	IM	Hoshizaki	IM	<1 ppb		10/02/2026 05:30	No Further Action	
20	3815-16	2	1	Weight Room	WC	Elkay - ezH20	Water fountain to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
21	3815-17	2	1	Weight Room	WC	Elkay - ezH20	Water fountain to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
22	3815-18	1	1	Indoor/Outdoor Training Center - Near the track	WC	Elkay - ezH20	WF to the far left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
23	3815-19	1	1	Indoor/Outdoor Training Center - Near the track	WC	Elkay - ezH20	BF 2nd from left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
24	3815-20	1	1	Indoor/Outdoor Training Center - Near the track	WC	Elkay - ezH20	WF 2nd from left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
25	3815-21	1	1	Indoor/Outdoor Training Center - Near the track	WC	Elkay - ezH20	WF 3rd from left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
26	3815-22	1	1	Indoor/Outdoor Training Center - Near the track	WC	Elkay - ezH20	BF to the far right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
27	3815-23	1	1	Indoor/Outdoor Training Center - Near the track	WC	Elkay - ezH20	WF to the far right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
28	3815-24	1	1	Indoor/Outdoor Training Center - Consessions	IM	Manitowoc	IM	<1 ppb		10/02/2026 05:30	No Further Action	
29	3815-25	4	1	STEM Academy - Across Room A105	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
30	3815-26	4	1	STEM Academy - Across Room A105	WC	Elkay - ezH20	Bottle filler to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
31	3815-27	4	1	STEM Academy - Across Room A105	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
32	3815-28	4	2	STEM Academy - Across Room A205	WC	Elkay - ezH20	Bottle filler to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
33	3815-29	4	2	STEM Academy - Across Room A205	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
34	3815-30	4	2	STEM Academy - Across Room A205	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
35	3815-31	4	2	STEM Academy - Behind A205, near the elevator	WC	Elkay - ezH20	BF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
36	3815-32	4	2	STEM Academy - Behind A205, near the elevator	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
37	3815-33	4	2	STEM Academy - Behind A205, near the elevator	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
38	3815-34	4	2	STEM Academy - Kitchen prep room	KF		KF in the back	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
39	3815-35	4	2	STEM Academy - Kitchen Cooking area	KF		Sink to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
40	3815-36	4	2	STEM Academy - Kitchen Cooking area	KF		Sink to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
41	3815-37	4	2	STEM Academy - Chickasaw Market	KF		KF in the back	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
42	3815-39	4	2	STEM Academy - On the Fly	IM	ICE o-matic	IM	<1 ppb		10/02/2026 05:30	No Further Action	
43	3815-65	5	3	MSB Bld - Across Room 307	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
44	3815-40	5	1	MSB Bld - East Hallway	WC	Elkay	WF in the hallway	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
45	3815-41	5	1	MSB Bld - Across attendance office	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
46	3815-42	5	1	MSB Bld - Across attendance office	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
47	3815-43	5	1	MSB Bld - Across attendance office	WC	Elkay - ezH20	BF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
48	3815-46	5	1	MSB Bld - Across Room 106	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
49	3815-47	5	1	MSB Bld - Across Room 106	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
50	3815-48	5	2	MSB Bld - Across Room 212	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
51	3815-49	5	2	MSB Bld - Across Room 212	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
52	3815-50	5	2	MSB Bld - Across Room 209	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
53	3815-51	5	2	MSB Bld - Across Room 209	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
54	3815-52	5	2	MSB Bld - To the right of Room 200	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
55	3815-53	5	2	MSB Bld - To the right of Room 200	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
56	3815-54	5	2	MSB Bld - To the right of 219	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
57	3815-55	5	2	MSB Bld - To the right of 219	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
58	3815-56	5	3	MSB Bld - To the right of Room 320	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
59	3815-57	5	3	MSB Bld - To the right of Room 320	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
60	3815-58	5	3	MSB Bld - Next to room 313	WC	Elkay - ezH20	Bottle Filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
61	3815-59	5	3	MSB Bld - Next to room 313	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
62	3815-60	5	3	MSB Bld - Room 313 (Food Economics)	CF		Classroom Sink - back left (closer to the entrance)	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
63	3815-61	5	3	MSB Bld - Room 313 (Food Economics)	CF		Classroom Sink - back center	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
64	3815-62	5	3	MSB Bld - Room 313 (Food Economics)	CF		Classroom Sink - back right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
65	3815-63	5	3	MSB Bld - Room 313 (Food Economics)	CF		Classroom Sink - front right (farthest from the entrance)	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
66	3815-64	5	3	MSB Bld - Across Room 307	WC	Elkay - ezH20	Bottle filler	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
67	3815-66	5	3	MSB Bld - Across Room 304	WC	Elkay - ezH20	Water fountain	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
68	3815-67	5	1	MSB Bld - Main office	WC	Elkay - ezH20	Bottle filler - in the back	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
69	3815-68	5	1	MSB Bld - Main office	WC	Elkay - ezH20	Water fountain - in the back	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
70	3815-69	5	1	MSB Bld - Main office	KF		Sink next to the fridge	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
71	3815-70	5	1	MSB Bld - Cafeteria	WC	Elkay	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
72	3815-71	5	1	MSB Bld - Cafeteria	WC	Elkay	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
73	3815-72	6	1	P Bld - Behind Volleyball Court	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
74	3815-73	6	1	P Bld - Behind Volleyball Court	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
75	3815-74	6	1	P Bld - Room P105	CF		Classroom Sink	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
76	3815-75	6	1	P Bld - Room P121	KF		Kitchen sink in the back	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
77	3815-76	7	1	Concert Hall - Near Main Office	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
78	3815-77	7	1	Concert Hall - Near Main Office	WC	Elkay - ezH20	BF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
79	3815-78	7	1	Concert Hall - Near Main Office	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
80	3815-79	7	1	Concert Hall - Hall Auditorium Entrance	WC	Elkay - ezH20	WF to the left	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
81	3815-80	7	1	Concert Hall - Hall Auditorium Entrance	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
82	3815-81	7	1	Concert Hall - Hall Auditorium Entrance	WC	Elkay - ezH20	BF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
83	3815-83	7	2	Concert Hall - To the right of the elevator	WC	Elkay - ezH20	WF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	
84	3815-84	7	2	Concert Hall - To the right of the elevator	WC	Elkay - ezH20	BF to the right	<1 ppb	<1 ppb	10/02/2026 05:30	No Further Action	