



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Purcell Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 02/03/2026 from 809 North Ninth Avenue, Purcell, OK 73080.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3991-10	1	1	Elementary building kitchen	KF		3 compartment sink in dish washing room, middle faucet	4.32 ppb	<1 ppb	2/3/2026 6:00:00 AM	Remediation Recommended	
2	3991-6	1	1	Elementary school kitchen	KF		Back wall, left of stoves, 3 compartment sink, left faucet	1.78 ppb	<1 ppb	2/3/2026 6:00:00 AM	Remediation Recommended	
3	3991-7	1	1	Elementary school kitchen	KF		Back wall, left of stoves, 3 compartment sink sprayer	1.29 ppb	<1 ppb	2/3/2026 6:00:00 AM	Remediation Recommended	
4	3991-9	1	1	Elementary building kitchen	KF		3 compartment sink in dish washing room, far left	1.2 ppb	<1 ppb	2/3/2026 6:00:00 AM	Remediation Recommended	
5	3991-4	1	1	Room 34 elementary building	CF		2 compartment sink, right of door wall	<1 ppb	<1 ppb	2/3/2026 6:15:00 AM	No Further Action	
6	3991-2	1	1	Room 32	CF		2 compartment faucet, left of door wall	<1 ppb	<1 ppb	2/3/2026 6:15:00 AM	No Further Action	
7	3991-5	1	1	Room 33 elementary building	CF		Single compartment sink, left of door wall	<1 ppb	<1 ppb	2/3/2026 6:15:00 AM	No Further Action	
8	3991-3	1	1	Room 31 elementary building	CF		Single compartment sink, right of door wall	<1 ppb	<1 ppb	2/3/2026 6:15:00 AM	No Further Action	

