



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Perry Jhs Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 07/29/2026
from 903 N 15Th Street, Perry, OK 73077.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	4068-8	1	1	Kitchen	KF		1 compartment faucet, across from oven	3.74 ppb	<1 ppb	07/29/2026 07:53	Remediation Recommended	
2	4068-4	1	1	Cafeteria	WC	MURDOCK	Right bottle filler	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
3	4068-5	1	1	Cafeteria	WC	MURDOCK	Right fountain	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
4	4068-3	1	1	Left of 112	WC	MURDOCK	Left fountain	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
5	4068-1	1	1	Right of 112	WC	MURDOCK	Right bottle filler	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
6	4068-2	1	1	right of 112	WC	MURDOCK	Right fountain	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
7	4068-6	1	1	Cafeteria	WC	MURDOCK	Left fountain	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
8	4068-9	1	1	Kitchen	KF		Right pot filler	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
9	4068-10	1	1	Kitchen	KF		Left pot filler	<1 ppb	<1 ppb	07/29/2026 08:05	No Further Action	
10	4068-7	1	1	Kitchen	KF		1 compartment faucet, across from freezer	<1 ppb	<1 ppb	07/29/2026 07:53	No Further Action	
11	4068-11	1	1	Concessions	IM	FOLLETT	Single ice machine	<1 ppb		07/29/2026 08:05	No Further Action	
12	4068-12	1	1	Across from 240	WC	MURDOCK	Right bottle filler	<1 ppb	<1 ppb	07/29/2026 08:11	No Further Action	
13	4068-15	1	1	Across from 248	WC	MURDOCK	Right bottle filler	<1 ppb	<1 ppb	07/29/2026 08:11	No Further Action	
14	4068-13	1	1	Across from 240	WC	MURDOCK	Right fountain	<1 ppb	<1 ppb	07/29/2026 08:11	No Further Action	

[illegible]