



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Dewar Hs Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 07/10/2026 from 204 East 5Th Street, Dewar, OK 74431.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Buildin g #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	4334-3	2	1	Only classroom	CF		Right side, 2 compartment faucet	3.13 ppb	<1 ppb	7/10/2026 5:34:00 AM	Remediation Recommended	
2	4334-5	2	1	Only classroom	CF		Left side, 2 compartment faucet	2.61 ppb	<1 ppb	7/10/2026 5:34:00 AM	Remediation Recommended	
3	4334-4	2	1	Only classroom	CF		Middle, 2 compartment faucet	1.4 ppb	<1 ppb	7/10/2026 5:34:00 AM	Remediation Recommended	
4	4334-2	1	1	Across from library	WC	ELKAY EXH2O LZWSSM_1A	Right bottle filler	<1 ppb	<1 ppb	7/10/2026 5:34:00 AM	No Further Action	
5	4334-1	1	1	Across from library	WC	ELKAY EHFSA8_1G	Left fountain	<1 ppb	<1 ppb	7/10/2026 5:34:00 AM	No Further Action	
6	4334-6	3	1	Gym	WC	ELKAY EZH2O LZWSSM_1A	Bottle filler	<1 ppb	<1 ppb	7/10/2026 5:34:00 AM	No Further Action	
7	4334-8	4	1	Cafeteria	WC	ELKAY EZFSTL8_1C	Right fountain	<1 ppb	<1 ppb	7/10/2026 5:34:00 AM	No Further Action	
8	4334-7	4	1	Cafeteria	WC	ELKAY EZH2O LZWSSM_1A	Left bottle filler	<1 ppb	<1 ppb	7/10/2026 5:34:00 AM	No Further Action	