



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Perkins-Tryon Intermediate Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 06/30/2026
from 1114 E Kirk, Perkins, OK 74059.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	4402-21	1	1	Kitchen	KF		Pot filler, left of prep bar	84 ppb	2.27 ppb	6/30/2026 7:55:00 AM	Remediation Strongly Suggested	
2	4402-23	1	1	Kitchen	KF		Pot filler, across from walk in freezer	13.9 ppb	2.11 ppb	6/30/2026 8:25:00 AM	Remediation Strongly Suggested	
3	4402-22	1	1	Kitchen	KF		1 compartment faucet, across from walk in freezer	10.1 ppb	1.19 ppb	6/30/2026 8:25:00 AM	Remediation Strongly Suggested	
4	4402-20	1	1	Kitchen	KF		Pot filler, right of prep bar	6.16 ppb	<1 ppb	6/30/2026 7:55:00 AM	Remediation Recommended	
5	4402-19	1	1	Kitchen	KF		2 compartment faucet, across from walk in freezer	1.19 ppb	<1 ppb	6/30/2026 7:55:00 AM	Remediation Recommended	
6	4402-1	1	1	Hallway between cafeteria and gym	WC	ELKAY EZH20 LZWSR_1D	Left bottle filler	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
7	4402-2	1	1	Hallway between cafeteria and gym	WC	ELKAY EZH20 LZWSR_1D	Left fountain	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
8	4402-6	1	1	Between 302 and 300	WC	ELKAY EZH20 LZWSR_1D	Right fountain	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
9	4402-3	1	1	Hallway between cafeteria and gym	WC	ELKAY EZH20 LZWSR_1D	Right fountain	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
10	4402-4	1	1	Between 302 and 300	WC	ELKAY EZH20 LZWSR_1D	Left bottle filler	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
11	4402-5	1	1	Between 302 and 300	WC	ELKAY EZH20 LZWSR_1D	Left fountain	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
12	4402-9	1	1	Right of 500	WC	ELKAY EZH20 LZWSR_1D	Left bottle filler	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
13	4402-7	1	1	Left of 401	WC	ELKAY EZH20 LZWSR_1D	Left bottle filler	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
14	4402-10	1	1	Right of 500	WC	ELKAY EZH20 LZWSR_1D	Left fountain	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	
15	4402-8	1	1	Left of 402	WC	ELKAY EZH20 LZWSR_1D	Right fountain	<1 ppb	<1 ppb	6/30/2026 7:40:00 AM	No Further Action	
16	4402-11	1	1	Right of 500	WC	ELKAY EZH20 LZWSR_1D	Right fountain	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	
17	4402-12	1	1	Cafeteria	WC	ELKAY EZH20 LZWSR_1D	Left side, left bottle filler	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	
18	4402-15	1	1	Cafeteria	WC	ELKAY EZH20 LZWSR_1D	Right side, left bottle filler	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	
19	4402-13	1	1	Cafeteria	WC	ELKAY EZH20 LZWSR_1D	Left side, left fountain	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	
20	4402-14	1	1	Cafeteria	WC	ELKAY EZH20 LZWSR_1D	Left side, right fountain	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	
21	4402-16	1	1	Cafeteria	WC	ELKAY EZH20 LZWSR_1D	Right side, left fountain	<1 ppb	<1 ppb	6/30/2026 7:55:00 AM	No Further Action	

[illegible]