



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Emerson Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 06/09/2026 from 1200 West Hickory, Duncan, OK 73533.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	4607-19	1	1	104	CF		Single white classroom faucet	6.49 ppb	<1 ppb	6/9/2026 7:50:00 AM	Remediation Recommended	
2	4607-18	1	1	109	CF		Drinking faucet attached to classroom faucet	5.52 ppb	2.1 ppb	6/9/2026 7:50:00 AM	Remediation Recommended	
3	4607-23	1	1	106	CF		Single white classroom faucet	5.23 ppb	1.62 ppb	6/9/2026 8:05:00 AM	Remediation Recommended	
4	4607-24	1	1	106	CF		Drinking faucet connected to classroom faucet	<1 ppb	4.33 ppb	6/9/2026 8:05:00 AM	Remediation Recommended	
5	4607-21	1	1	107	CF		Single white classroom faucet	2.39 ppb	<1 ppb	6/9/2026 7:59:00 AM	Remediation Recommended	
6	4607-17	1	1	109	CF		Single white classroom faucet	1.97 ppb	<1 ppb	6/9/2026 7:50:00 AM	Remediation Recommended	
7	4607-22	1	1	107	CF		Drinking faucet connected to classroom faucet	1.49 ppb	1.8 ppb	6/9/2026 8:05:00 AM	Remediation Recommended	
8	4607-25	1	1	Library hallway	WC	ELKAY EHGSA8_1K	In between Custodian closet and teachers lounge	1.78 ppb	<1 ppb	6/9/2026 8:05:00 AM	Remediation Recommended	
9	4607-5	1	1	115	CF		Single white classroom faucet	1.61 ppb	<1 ppb	6/9/2026 7:25:00 AM	Remediation Recommended	
10	4607-7	1	1	103	CF		Single silver faucet	1.58 ppb	<1 ppb	6/9/2026 7:25:00 AM	Remediation Recommended	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
11	4607-3	1	1	Front entrance hallway	DW		Single white drinking outlet with 2 drinking faucets, across from nurses offices	1.3 ppb	<1 ppb	6/9/2026 7:25:00 AM	Remediation Recommended	
12	4607-16	1	1	Kitchen	KF		Single silver faucet, right of oven, across from serving line	1.2 ppb	<1 ppb	6/9/2026 7:50:00 AM	Remediation Recommended	
13	4607-8	1	1	103	CF		Drinking water faucet attached to single silver faucet	1.18 ppb	<1 ppb	6/9/2026 7:25:00 AM	Remediation Recommended	
14	4607-1	1	1	Front entrance hallway	WC	Elkay ezh2o	Top bottle filler, Across from nurses office, filter status yellow	<1 ppb	<1 ppb	6/9/2026 7:25:00 AM	No Further Action	
15	4607-2	1	1	Front entrance hallway	WC	Elkay LZS8WSLP	Bottom water cooler, across from nurses office	<1 ppb	<1 ppb	6/9/2026 7:25:00 AM	No Further Action	
16	4607-4	1	1	Entrance hallway	DW		Single white drinking outlet with 2 drinking faucets, across from nurses office	<1 ppb	<1 ppb	6/9/2026 7:25:00 AM	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
17	4607-6	1	1	115	CF		Drinking faucet attached to single white classroom faucet	<1 ppb	<1 ppb	6/9/2026 7:25:00 AM	No Further Action	
18	4607-9	1	1	Left of room 103	WC	Elkay exh2o	Top bottle filler, Left of room 103	<1 ppb	<1 ppb	6/9/2026 7:25:00 AM	No Further Action	
19	4607-10	1	1	Left of room 103	WC	Elkay LZS8WSLP	Bottom water cooler, across from cafeteria	<1 ppb	<1 ppb	6/9/2026 7:35:00 AM	No Further Action	
20	4607-11	1	1	Room 121	CF		Single silver classroom faucet	<1 ppb	<1 ppb	6/9/2026 7:35:00 AM	No Further Action	
21	4607-12	1	1	Room 121	CF		Drinking faucet attached to single silver classroom faucet	<1 ppb	<1 ppb	6/9/2026 7:35:00 AM	No Further Action	
22	4607-13	1	1	Cafeteria	WC	Elkay ezh2o	Single top bottle filler, filter status yellow	<1 ppb	<1 ppb	6/9/2026 7:35:00 AM	No Further Action	
23	4607-14	1	1	Cafeteria	WC	Elkay	Bottom single water cooler	<1 ppb	<1 ppb	6/9/2026 7:35:00 AM	No Further Action	
24	4607-15	1	1	Kitchen	IM	Koolaire	Back of kitchen	<1 ppb		6/9/2026 7:35:00 AM	No Further Action	
25	4607-26	1	1	Across from room 134	WC	ELKAY EZH20	Top bottle filler, filter yellow	<1 ppb	<1 ppb	6/9/2026 8:05:00 AM	No Further Action	
26	4607-27	1	1	Across from room 134	WC	ELKAY ENLZ8WS_1f	Bottom water cooler	<1 ppb	<1 ppb	6/9/2026 8:05:00 AM	No Further Action	

[illegible]