



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Mark Twain Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 06/09/2026
from 2204 West Oak Avenue, Duncan, OK 73533.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	4610-3	1	1	37	CF		Single silver classroom faucet	4.72 ppb	<1 ppb	6/9/2026 8:23:00 AM	Remediation Recommended	
2	4610-7	3	1	Kitchen	KF		3 compartment faucet, left corner	4.21 ppb	1.06 ppb	6/9/2026 8:23:00 AM	Remediation Recommended	
3	4610-1	1	1	Main building hallway	WC	Elkay ezh2o	Between room 40 and 39	<1 ppb	<1 ppb	6/9/2026 8:23:00 AM	No Further Action	
4	4610-2	1	1	Main building hallway	WC	Elkay LZS8WSSP	Bottom water cooler inbetween 40 and 39	<1 ppb	<1 ppb	6/9/2026 8:23:00 AM	No Further Action	
5	4610-4	1	1	37	CF		Drinking faucet attached to single silver classroom faucet	<1 ppb	<1 ppb	6/9/2026 8:23:00 AM	No Further Action	
6	4610-5	2	1	Building B left of room 22	WC	Elkay ezh2o	Top bottle filler	<1 ppb	<1 ppb	6/9/2026 8:23:00 AM	No Further Action	
7	4610-6	2	1	Building B, left of room 22	WC	Elkay LZS8WSSP	Bottom water cooler	<1 ppb	<1 ppb	6/9/2026 8:23:00 AM	No Further Action	
8	4610-8	3	1	Kitchen	IM	Manitowoc	Single ice machine in kitchen	<1 ppb		6/9/2026 8:23:00 AM	No Further Action	
9	4610-9	3	1	Building C, hallway	WC	Elkay exh2o	Right of room 9	<1 ppb	<1 ppb	6/9/2026 8:42:00 AM	No Further Action	
10	4610-10	3	1	Building C, hallway	WC	Elkay LZS8WSSP	Bottom water cooler, right of room 9	<1 ppb	<1 ppb	6/9/2026 8:46:00 AM	No Further Action	

[illegible]