



OKLAHOMA DRINKING WATER

**LEAD TESTING**

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

## Woodrow Wilson Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma  
Lead in Schools and Child Care Program (LWSC) on 06/09/2026  
from 800 E. Chestnut Avenue, Duncan, OK 73533.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

| # | Outlet ID | Building # | Floor # | Room # / Name                                              | Outlet Type Code | Water Cooler Make and Model | Comments                                      | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed?          | Remediation Action Taken |
|---|-----------|------------|---------|------------------------------------------------------------|------------------|-----------------------------|-----------------------------------------------|---------------------------------------|---------------------------------------|------------------------|-------------------------|--------------------------|
| 1 | 4611-29   | 1          | 1       | Pre k room connected to building 1                         | CF               |                             | Single silver classroom faucet                | 9.36 ppb                              | <1 ppb                                | 6/9/2026 7:00:00 AM    | Remediation Recommended |                          |
| 2 | 4611-27   | 1          | 1       | Special needs room connected to building 1                 | CF               |                             | Single silver classroom faucet                | 7.99 ppb                              | <1 ppb                                | 6/9/2026 7:00:00 AM    | Remediation Recommended |                          |
| 3 | 4611-8    | 1          | 1       | Kitchen                                                    | KF               | Groen                       | Pot filler back of kitchen wall               | 5.97 ppb                              | <1 ppb                                | 6/9/2026 6:30:00 AM    | Remediation Recommended |                          |
| 4 | 4611-22   | 2          | 1       | A6                                                         | DW               |                             | Drinking faucet connected to classroom faucet | 2.53 ppb                              | <1 ppb                                | 6/9/2026 7:00:00 AM    | Remediation Recommended |                          |
| 5 | 4611-16   | 2          | 1       | A3                                                         | DW               |                             | Drinking faucet connected to classroom faucet | 1.02 ppb                              | <1 ppb                                | 6/9/2026 6:40:00 AM    | Remediation Recommended |                          |
| 6 | 4611-1    | 1          | 1       | Between boys and girl restroom, across from counselor room | WC               | Elkay EZH20                 | Top bottle filler                             | <1 ppb                                | <1 ppb                                | 6/9/2026 6:15:00 AM    | No Further Action       |                          |
| 7 | 4611-2    | 1          | 1       | Between boys and girl restroom, across from counselor room | WC               | Elkay LZS8WS_1F             | Bottom water cooler                           | <1 ppb                                | <1 ppb                                | 6/9/2026 6:15:00 AM    | No Further Action       |                          |
| 8 | 4611-3    | 1          | 1       | Middle of cafeteria doors                                  | WC               | ELKAY                       | Left tall water cooler                        | <1 ppb                                | <1 ppb                                | 6/9/2026 6:15:00 AM    | No Further Action       |                          |
| 9 | 4611-4    | 1          | 1       | Between cafeteria doors                                    | WC               | Elkay EZH20                 | Top right bottle filler                       | <1 ppb                                | <1 ppb                                | 6/9/2026 6:15:00 AM    | No Further Action       |                          |

| #  | Outlet ID | Building # | Floor # | Room # / Name           | Outlet Type Code | Water Cooler Make and Model | Comments                                                          | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed?    | Remediation Action Taken |
|----|-----------|------------|---------|-------------------------|------------------|-----------------------------|-------------------------------------------------------------------|---------------------------------------|---------------------------------------|------------------------|-------------------|--------------------------|
| 10 | 4611-5    | 1          | 1       | Between cafeteria doors | WC               | ELKAY LZSTL8WSS P           | Right short bottom water cooler                                   | <1 ppb                                | <1 ppb                                | 6/9/2026 6:15:00 AM    | No Further Action |                          |
| 11 | 4611-6    | 1          | 1       | Kitchen                 | KF               |                             | 2 compartment, across from only freezer and cooler                | <1 ppb                                | <1 ppb                                | 6/9/2026 6:15:00 AM    | No Further Action |                          |
| 12 | 4611-7    | 1          | 1       | Kitchen                 | IM               | Manitowoc s400              | Across from cooler and freezer                                    | <1 ppb                                |                                       | 6/9/2026 6:15:00 AM    | No Further Action |                          |
| 13 | 4611-9    | 1          | 1       | Gymnasium bathroom      | WC               | Elkay EZH20                 | Top bottle filler                                                 | <1 ppb                                | <1 ppb                                | 6/9/2026 6:30:00 AM    | No Further Action |                          |
| 14 | 4611-10   | 1          | 1       | Gymnasium bathroom      | WC               | ELKAY LZS8WSSP              | Bottom water cooler                                               | <1 ppb                                | <1 ppb                                | 6/9/2026 6:35:00 AM    | No Further Action |                          |
| 15 | 4611-11   | 2          | 1       | A1                      | CF               |                             | Building A room A1                                                | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 16 | 4611-12   | 2          | 1       | A1                      | DW               |                             | Drinking faucet connected to classroom faucet, building A room A1 | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 17 | 4611-13   | 2          | 1       | A2                      | CF               |                             | Single silver classroom faucet                                    | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 18 | 4611-14   | 2          | 1       | A2                      | DW               |                             | Drinking faucet connected to classroom faucet                     | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 19 | 4611-15   | 2          | 1       | A3                      | CF               |                             | Single silver classroom faucet                                    | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |

| #  | Outlet ID | Building # | Floor # | Room # / Name                                   | Outlet Type Code | Water Cooler Make and Model | Comments                                      | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed?    | Remediation Action Taken |
|----|-----------|------------|---------|-------------------------------------------------|------------------|-----------------------------|-----------------------------------------------|---------------------------------------|---------------------------------------|------------------------|-------------------|--------------------------|
| 20 | 4611-17   | 2          | 1       | A4                                              | CF               |                             | Single silver classroom faucet                | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 21 | 4611-18   | 2          | 1       | A4                                              | DW               |                             | Drinking faucet connected to classroom faucet | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 22 | 4611-19   | 2          | 1       | A5                                              | CF               |                             | Single silver classroom faucet                | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 23 | 4611-20   | 2          | 1       | A5                                              | DW               |                             | Drinking faucet connected to classroom faucet | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 24 | 4611-21   | 2          | 1       | A6                                              | CF               |                             | Single silver classroom faucet                | <1 ppb                                | <1 ppb                                | 6/9/2026 6:40:00 AM    | No Further Action |                          |
| 25 | 4611-23   | 3          | 1       | Building B only girls restroom                  | WC               | Hasley taylor HTV8Q_1A      | Single water cooler, right infront of door    | <1 ppb                                | <1 ppb                                | 6/9/2026 7:00:00 AM    | No Further Action |                          |
| 26 | 4611-24   | 3          | 1       | Building B only boys restroom                   | WC               | ELKAY EZFS8_1C              | Single water cooler, infront of door          | <1 ppb                                | <1 ppb                                | 6/9/2026 7:00:00 AM    | No Further Action |                          |
| 27 | 4611-25   | 4          | 1       | Building C only boys restroom                   | WC               | ELKAY EHFS8_1G              | Single water cooler in restroom               | <1 ppb                                | <1 ppb                                | 6/9/2026 7:00:00 AM    | No Further Action |                          |
| 28 | 4611-26   | 4          | 1       | Building C only girls restroom                  | WC               | ELKAY EZFS8_1H              | Single water cooler in restroom               | <1 ppb                                | <1 ppb                                | 6/9/2026 7:00:00 AM    | No Further Action |                          |
| 29 | 4611-28   | 1          | 1       | Special needs classroom connected to building 1 | DW               |                             | Drinking Faucet connected to classroom faucet | <1 ppb                                | <1 ppb                                | 6/9/2026 7:00:00 AM    | No Further Action |                          |

[illegible]