



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Duncan Hs Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 06/10/2026
from 1325 N. 19Th Street, Duncan, OK 73533.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	4614-19	2	1	Front of auditorium	WC	CAMMP	In front of mens restroom	2.3 ppb	4.18 ppb	6/10/2026 6:40:00 AM	Remediation Recommended	
2	4614-2	1	1	Kitchen	KF		Left Pot Filler	2.72 ppb	<1 ppb	6/10/2026 6:15:00 AM	Remediation Recommended	
3	4614-1	1	1	Kitchen	KF		Right Pot filler	1.27 ppb	<1 ppb	6/10/2026 6:15:00 AM	Remediation Recommended	
4	4614-4	1	1	Kitchen	KF		2 compartment back of kitchen	<1 ppb	1.09 ppb	6/10/2026 6:25:00 AM	Remediation Recommended	
5	4614-3	1	1	Kitchen	IM	Manitowoc B570	Ice machine across from ovens	<1 ppb		6/10/2026 6:15:00 AM	No Further Action	
6	4614-5	1	1	Across from room E1	WC	ELKAY EZH2O	Left tall bottle filler	<1 ppb	<1 ppb	6/10/2026 6:25:00 AM	No Further Action	
7	4614-6	1	1	Across from room E1	WC	EZFSTL8_1B	Left tall fountain	<1 ppb	<1 ppb	6/10/2026 6:25:00 AM	No Further Action	
8	4614-7	1	1	Across from room E1	WC	EZFSTL8_1B	Right bottom fountain	<1 ppb	<1 ppb	6/10/2026 6:25:00 AM	No Further Action	
9	4614-8	1	2	Across from room E3	WC	ELKAY EZH2O	Top left tall bottle filler	<1 ppb	<1 ppb	6/10/2026 6:25:00 AM	No Further Action	
10	4614-9	1	2	Across from room E3	WC	EZFSTL8_1B	Left tall fountain	<1 ppb	<1 ppb	6/10/2026 6:25:00 AM	No Further Action	
11	4614-10	1	2	Across from room E3	WC	EZFSTL8_1B	Right bottom fountain	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
12	4614-11	1	2	Across from room 235	WC	ELKAY EZH2O	Top left bottle filler	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
13	4614-12	1	2	Across from room 235	WC	EZFSTL8_1B	Bottom Left fountain	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
14	4614-13	1	2	Across from room 235	WC	EZFSTL8_1B	Right fountain	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
15	4614-14	1	1	Left of room 194	WC	ELKAY EZH2O	Top left bottle filler	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
16	4614-15	1	1	Left of room 194	WC	EZFSTL8_1B	Left fountain	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
17	4614-16	1	1	Left of room 194	WC	EZFSTL8_1B	Right fountain	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
18	4614-17	2	1	Across room A-1	WC	ELKAY EZH2O	Top bottle filler	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
19	4614-18	2	1	Across room A-1	WC	EZFSTL8_1B	Bottom fountain	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
20	4614-20	2	1	Front of auditorium	WC	CAMMP	In front of women's restroom	<1 ppb	<1 ppb	6/10/2026 6:40:00 AM	No Further Action	
21	4614-22	2	1	Storm shelter	WC	EZFSTL8_1B	Left fountain	<1 ppb		6/10/2026 7:10:00 AM	No Further Action	
22	4614-21	2	1	Storm shelter	WC	ELKAY EZH2O	Right bottle filler		<1 ppb		No Further Action	
23	4614-23	2	1	Storm shelter	WC	EZFSTL8_1B	Right fountain	<1 ppb	<1 ppb	6/10/2026 7:10:00 AM	No Further Action	
24	4614-24	2	1	Across from A-2	WC	ELKAY EZH2O	Top bottle filler	<1 ppb	<1 ppb	6/10/2026 7:10:00 AM	No Further Action	
25	4614-25	2	1	Across from room A-1	WC	EZFSTL8_1B	Bottom fountain	<1 ppb	<1 ppb	6/10/2026 7:10:00 AM	No Further Action	
26	4614-26	3	1	West building, front lobby	WC	ELKAY EZH2O	Left of boys restroom, bottle filler	<1 ppb	<1 ppb	6/10/2026 7:10:00 AM	No Further Action	
27	4614-27	3	1	West building, front lobby	WC	EZFSTL8_1B	Left of boys restroom, bottom fountain	<1 ppb		6/10/2026 7:10:00 AM	No Further Action	
28	4614-28	3	1	Right of W108	WC	ELKAY EZH2O	Left bottle filler	<1 ppb	<1 ppb	6/10/2026 7:10:00 AM	No Further Action	
29	4614-29	3	1	Across from room W108	WC	EZFSTL8_1B	Left fountain	<1 ppb	<1 ppb	6/10/2026 7:10:00 AM	No Further Action	

[illegible]