



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Progressive Steps Inc Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 08/04/2026
from 1832 NE 50th St, Oklahoma City, OK 73111.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	5110-6	1	1	Bathroom nearest outlet 5	BF			<1 ppb	3.03 ppb	08/04/2026 06:30	Remediation Recommended	
2	5110-4	1	1	Bathroom sink	BF		Right	2.37 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	
3	5110-5	1	1	Classroom next kitchen	CF			2.23 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	
4	5110-1	1	1	Kitchen	KF		Lower left faucet	1.76 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	
5	5110-3	1	1	Bathroom sink	BF		Left	1.43 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	
6	5110-7	1	1	Classroom with sleep area	CF			1.42 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	
7	5110-8	1	1	Bathroom inside of classroom with sleep area	BF			1.28 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	
8	5110-2	1	1	Kitchen (Krowne - HS-9L)	KF	(Krowne - HS-9L)	Upper right faucet	1.26 ppb	<1 ppb	08/04/2026 06:30	Remediation Recommended	