



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Kidlinx Child Care Academy, Inc. Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 07/31/2026
from 301 N. 16th Street, Durant, OK 74701.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

[illegible]