



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Wiggles And Giggles Preschool, Llc Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 08/25/2026
from 5004 N PORTLAND AVE
, SUITE B, Oklahoma City, OK 73112.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Buildin g #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	5132-1	1	1	Bathroom	BF		Infants room bathroom in the back	3.91 ppb	<1 ppb	08/25/2026 07:00	Remediation Recommended	
2	5132-2	1	1	Bathroom	BF		Toddlers room bathroom	2.37 ppb	<1 ppb	08/25/2026 07:00	Remediation Recommended	
3	5132-6	1	1	Bathroom	BF		Bathroom near the entrance to the right	1.32 ppb	<1 ppb	08/25/2026 07:00	Remediation Recommended	
4	5132-5	1	1	Bathroom	BF		Bathroom near the entrance to the left	1.23 ppb	<1 ppb	08/25/2026 07:00	Remediation Recommended	
5	5132-4	1	1	Kitchen	KF		Sink to the right	<1 ppb	<1 ppb	08/25/2026 07:00	No Further Action	
6	5132-3	1	1	Kitchen	KF		Sink to the left	<1 ppb	<1 ppb	08/25/2026 07:00	No Further Action	
7	5132-8	1	1	Main entrance	WC	Elkay	Water cooler to right bottom	<1 ppb	<1 ppb	08/25/2026 07:00	No Further Action	
8	5132-7	1	1	Main entrance	WC	Elkay	Water cooler to left top	<1 ppb	<1 ppb	08/25/2026 07:00	No Further Action	