



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Millwood Early Childhood Academy Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 04/10/2026 from 6706 N. Martin Luther King Blvd., Oklahoma City, OK 73111.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	5141-8	1	1	Room B	BF		Only Bathroom in Room b, right of door	2.1 ppb	<1 ppb	04/10/2026 06:45	Remediation Recommended	
2	5141-5	1	1	Room A	BF		Only Bathroom in room A, back of room	1.39 ppb	<1 ppb	04/10/2026 06:30	Remediation Recommended	
3	5141-1	1	1	Resource room	KF		2 compartment faucet right wall	<1 ppb	<1 ppb	04/10/2026 06:30	No Further Action	
4	5141-2	1	1	Resource room	IM	Manitowoc	Single standing ice machine right wall	<1 ppb		04/10/2026 06:30	No Further Action	
5	5141-3	1	1	Room A	CF		Left tall single faucet, on door wall	<1 ppb	<1 ppb	04/10/2026 06:30	No Further Action	
6	5141-4	1	1	Room A	CF		Right short faucet, on door wall	<1 ppb	<1 ppb	04/10/2026 06:30	No Further Action	
7	5141-6	1	1	Room B	CF		Left short faucet, on back wall	<1 ppb	<1 ppb	04/10/2026 06:45	No Further Action	
8	5141-7	1	1	Room B	CF		Right tall faucet, on back wall	<1 ppb	<1 ppb	04/10/2026 06:45	No Further Action	
9	5141-9	1	1	Room C	CF		Left tall faucet, right of door	<1 ppb	<1 ppb	04/10/2026 06:45	No Further Action	

