



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

## Perry Lower Es Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma  
Lead in Schools and Child Care Program (LWSC) on 07/24/2026  
from 1103 N. 15th Street, Perry, OK 73077.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

| #  | Outlet ID | Building # | Floor # | Room # / Name  | Outlet Type Code | Water Cooler Make and Model | Comments                      | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed?          | Remediation Action Taken |
|----|-----------|------------|---------|----------------|------------------|-----------------------------|-------------------------------|---------------------------------------|---------------------------------------|------------------------|-------------------------|--------------------------|
| 1  | 5363-16   | 1          | 1       | 157A           | CF               |                             | Single faucet                 | 1.75 ppb                              | <1 ppb                                | 07/24/2026 06:33       | Remediation Recommended |                          |
| 2  | 5363-3    | 1          | 1       | Kitchen        | KF               |                             | 2 compartment, right of ovens | 1.58 ppb                              | <1 ppb                                | 07/24/2026 06:13       | Remediation Recommended |                          |
| 3  | 5363-2    | 1          | 1       | Kitchen        | KF               |                             | 3 compartment, right faucet   | 1.17 ppb                              | <1 ppb                                | 07/24/2026 06:13       | Remediation Recommended |                          |
| 4  | 5363-15   | 1          | 1       | 158A           | DW               |                             | Bubbler                       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 5  | 5363-14   | 1          | 1       | 158A           | CF               |                             | Single faucet                 | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 6  | 5363-12   | 1          | 1       | Right of A161A | WC               | EZH20                       | Bottle filler                 | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 7  | 5363-11   | 1          | 1       | Left of A161A  | WC               |                             | Fountain                      | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 8  | 5363-13   | 1          | 1       | Right of A161A | WC               | ELKAY EZ H20LZWSR_1D        | Fountain                      | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 9  | 5363-20   | 1          | 1       | 155A           | CF               |                             | Single faucet                 | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 10 | 5363-17   | 1          | 1       | 157A           | DW               |                             | Bubbler                       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 11 | 5363-19   | 1          | 1       | 156A           | DW               |                             | Bubbler                       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 12 | 5363-18   | 1          | 1       | 156A           | CF               |                             | Single faucet                 | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action       |                          |
| 13 | 5363-23   | 1          | 1       | 151A           | DW               |                             | Bubbler                       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action       |                          |
| 14 | 5363-22   | 1          | 1       | 151A           | CF               |                             | Single faucet                 | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action       |                          |

| #  | Outlet ID | Building # | Floor # | Room # / Name | Outlet Type Code | Water Cooler Make and Model | Comments      | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed?    | Remediation Action Taken |
|----|-----------|------------|---------|---------------|------------------|-----------------------------|---------------|---------------------------------------|---------------------------------------|------------------------|-------------------|--------------------------|
| 15 | 5363-24   | 1          | 1       | Left of 144A  | WC               | ELKAY EZ H20LZWSR_1D        | Fountain      | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 16 | 5363-25   | 1          | 1       | Right of 144A | WC               | EZH20                       | Bottle filler | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 17 | 5363-21   | 1          | 1       | 155A          | DW               |                             | Bubbler       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action |                          |
| 18 | 5363-29   | 1          | 1       | 138A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 19 | 5363-26   | 1          | 1       | Right of 144A | WC               | ELKAY EZ H20LZWSR_1D        | Fountain      | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 20 | 5363-28   | 1          | 1       | 137A          | DW               |                             | Bubbler       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 21 | 5363-27   | 1          | 1       | 137A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 22 | 5363-30   | 1          | 1       | 138A          | DW               |                             | Bubbler       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 23 | 5363-31   | 1          | 1       | 139A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 24 | 5363-34   | 1          | 1       | 141A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 07:13       | No Further Action |                          |
| 25 | 5363-35   | 1          | 1       | 141A          | DW               |                             | Bubbler       | <1 ppb                                | <1 ppb                                | 07/24/2026 07:13       | No Further Action |                          |
| 26 | 5363-32   | 1          | 1       | 140A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 27 | 5363-33   | 1          | 1       | 140A          | DW               |                             | Bubbler       | <1 ppb                                | <1 ppb                                | 07/24/2026 06:58       | No Further Action |                          |
| 28 | 5363-36   | 1          | 1       | 149A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 07:13       | No Further Action |                          |
| 29 | 5363-37   | 1          | 1       | 108A          | CF               |                             | Single faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 07:13       | No Further Action |                          |

| #  | Outlet ID | Buidling # | Floor # | Room # / Name         | Outlet Type Code | Water Cooler Make and Model | Comments                   | Initial First Draw Result Final (ppb) | Initial Flush Draw Result Final (ppb) | Initial Sample Date(s) | Action Needed?    | Remediation Action Taken |
|----|-----------|------------|---------|-----------------------|------------------|-----------------------------|----------------------------|---------------------------------------|---------------------------------------|------------------------|-------------------|--------------------------|
| 30 | 5363-38   | 1          | 1       | Left of 117A          | CF               |                             | 2 compartment faucet       | <1 ppb                                | <1 ppb                                | 07/24/2026 07:13       | No Further Action |                          |
| 31 | 5363-10   | 1          | 1       | 163A                  | CF               |                             | Single faucet              | <1 ppb                                | <1 ppb                                | 07/24/2026 06:33       | No Further Action |                          |
| 32 | 5363-9    | 1          | 1       | 167A                  | CF               |                             | Single faucet              | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
| 33 | 5363-8    | 1          | 1       | 150A                  | DW               |                             | Bubbler                    | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
| 34 | 5363-6    | 1          | 1       | 176A                  | BF               |                             | Bathroom A174B             | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
| 35 | 5363-7    | 1          | 1       | 150A                  | CF               |                             | Single faucet              | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
| 36 | 5363-5    | 1          | 1       | Between B106 and B101 | WC               | ELKAY EZ H2OLZWSR_1D        | Fountain                   | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
| 37 | 5363-4    | 1          | 1       | Between B106 and B101 | WC               | ELKAY EZ H2OLZWSR_1D        | Bottle filler              | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
| 38 | 5363-1    | 1          | 1       | Kitchen               | KF               |                             | 3 compartment, left faucet | <1 ppb                                | <1 ppb                                | 07/24/2026 06:13       | No Further Action |                          |
|    |           |            |         |                       |                  |                             |                            |                                       |                                       |                        |                   |                          |