



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Santillan, Yesenia Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 08/18/2026 from 2705 SW 52ND ST, Oklahoma City, OK 73119.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	569-1	1	1	Kitchen	KF			1.78 ppb	<1 ppb	08/18/2026 06:30	Remediation Recommended	
2	569-3	1	1	Classroom	CF		Classroom with sleeping area	1.08 ppb	<1 ppb	08/18/2026 06:30	Remediation Recommended	
3	569-4	1	1	Bathroom	BF		Bathroom next to sleep area in back	<1 ppb	<1 ppb	08/18/2026 06:30	No Further Action	
4	569-2	1	1	Bathroom	BF		Bathroom in play area in the back	<1 ppb	<1 ppb	08/18/2026 06:30	No Further Action	