OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Jefferson, Meridith
Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 08/07/2026 from 1822 Opal, Clinton, OK 73601.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:
CF: Classroom Faucet
KF: Kitchen Faucet
BF: Bathroom Faucet
NS: Nurse Office Sink
RA: Refrigerator Appliance
OF: Outdoor Faucet
IM: Ice Machine
DW: Drinking Water Fountain
WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	588-1	1	1	Kitchen	KF		Single faucet	<1 ppb	<1 ppb	08/07/2026 05:10	No Further Action	
2	588-2	1	1	Main bathroom	BF		Single faucet	<1 ppb	<1 ppb	08/07/2026 05:10	No Further Action	