



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Anadarko Public School DistrictSchool: Anadarko East Elementary SchoolSampling Date: 8/1/2025Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Anadarko Public School District - Anadarko East Elementary School on August 1, 2025.

Overall, twenty (20) outlets were tested resulting in a total of forty (40) samples being sent to the lab.

- Twenty-two (22) samples had no detectable level of lead.
- Eighteen (18) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Hall across from room 7- standalone cooler	<1.0	<1.0	N/A
1-1-HALL-WC2	Hall across from room 16- top bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC3	Hall across from room 16- bottom water cooler	<1.0	<1.0	N/A
1-1-HALL-WC4	Hall across from room 23- left Halsey Taylor water cooler	<1.0	<1.0	N/A
1-1-HALL-WC6	Hall across from room 31- standalone water cooler	<1.0	<1.0	N/A
1-1-HALL-WC7	Hall between rooms 40 and 37- far left corner of the room	<1.0	<1.0	N/A
1-1-SAFE-WC1	Safe room- left water cooler	<1.0	<1.0	N/A
2-1-SAFE-WC1	Safe room- top right bottle filler	<1.0	<1.0	N/A
2-1-SAFE-WC2	Safe room- right bottom water cooler	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-40-CF1	Room 40 classroom faucet	<1.0	1.2	
1-1-37-CF1	Room 37 classroom faucet	1.3	<1.0	
1-1-KIT-KF4	Kitchen- Silver single compartment sprayer	1.9	1.5	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-KIT-KF2	Kitchen- single white faucet far right corner	2.4	1.7	
1-1-KIT-KF1	Kitchen- hose above groen device, far back wall	3.3	1.7	
1-1-7-CF2	Room 7 classroom faucet- back right wall	3.5	<1.0	
1-1-HALL-WC5	Hall across from room 23- right Halsey Taylor water cooler	3.5	2.5	
1-1-KIT-KF3	Kitchen- silver 2 compartment sink faucet	4.4	1.9	
1-1-7-CF1	Room 7 classroom faucet- right back wall (drinking spigot)	8.8	1.2	
1-1-4-CF2	Room 4 classroom faucet- left wall	10.1	1.8	
1-1-4-CF1	Room 4 classroom faucet- left wall drinking spigot	14.6	<1.0	