



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Anadarko Public School DistrictSchool: Anadarko High SchoolSampling Date: 6/5/2025Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Anadarko Public School District - Anadarko High School on June 5, 2025. Overall, twenty-six (26) outlets were tested resulting in a total of fifty-two (52) samples being sent to the lab.

- Thirty-four (34) samples had no detectable level of lead.
- Seventeen (17) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-ENT-WC1	Bottle filler in entry way next to men's bathroom	<1.0	<1.0	N/A
1-1-ENT-WC2	Fountain under bottle fill in entry way next to men's bathroom	<1.0	<1.0	N/A
1-1-CAFÉ-IM1	Cafeteria ice machine	<1.0	<1.0	N/A
2-1-CON-WC1	Right water fountain on the left of the concession stand	<1.0	<1.0	N/A
2-1-CON-KF1	Concession stand sink	<1.0	<1.0	N/A
2-1-CON-IM1	Concession stand ice machine (Manitowoc)	<1.0	<1.0	N/A
2-1-HALL-WC1	Fountains to the right of concessions. Left fountain	<1.0	<1.0	N/A
1-1-HALL-WC4	Fountains to the right of concessions. Right fountain	<1.0	<1.0	N/A
3-2-WR-WC1	Drinking fountain under bottle filler on right side in weight room	<1.0	<1.0	N/A
3-2-WR-WC2	Bottle filler on right side in weight room	<1.0	<1.0	N/A
3-2-WR-WC3	Left drinking fountain in weight room	<1.0	<1.0	N/A
3-1-HALL-WC1	Bottle filler on right side in first floor next to utility room	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
3-1-HALL-WC2	Fountain under bottle filler on right side on first floor next to utility room	<1.0	<1.0	N/A
3-1-HALL-WC3	Left Fountain on first floor closest to utility room	<1.0	<1.0	N/A
3-1-LR-WC1	Bottle filler in locker room next to assistant coach office	<1.0	<1.0	N/A
3-1-LR-WC2	Fountain underneath bottle filler in locker room next to assistant coach office	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-TL-KF1	Teachers' lounge faucet	1.3	<1.0	
1-1-ENT-WC3	Solo fountain to right of bottle fill station in entry way	1.9	1.7	
1-1-HALL-WC2	Across from room 226 art, right most fountain	1.7	1.9	
1-1-HER-KF1	Home Ec room left most sink	1.8	2.3	
1-1-HALL-WC3	Across from room art 226 art, left fountain	1.7	2.4	
1-1-HER-KF3	Home Ec right sink	2.0	2.5	
1-1-HER-KF2	Home Ec middle sink	4.2	<1.0	
1-1-CAFÉ-WC1	Cafeteria drinking fountain in corner	4.0	4.3	
1-1-HALL-WC1	Fountain to the right of classroom 155	4.9	6.6	
High Detection (≥15.0 µg/L)				
1-1-KIT-KF1	Cafeteria kitchen pot filler	90.7	1.1	