



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Beyond Learning Child Development Center

School: Beyond Learning Child Development Center

Sampling Date: 7/31/2025

Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Beyond Learning Child Development Center - Beyond Learning Child Development Center on July 31, 2025. Overall, eleven (11) outlets were tested resulting in a total of twenty-two (22) samples being sent to the lab.

- Twenty-one (21) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-KIT-KF1	Kitchen- right side single compartment faucet	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen- left 2 compartment sink back wall	<1.0	<1.0	N/A
1-1-EPREK-BF1	Early Pre-K (right of door) bathroom faucet	<1.0	<1.0	N/A
1-1-SCH-BF1	School aged- far left bathroom faucet	<1.0	<1.0	N/A
1-1-SCH-BF2	School aged-middle bathroom faucet	<1.0	<1.0	N/A
1-1-SCH-BF3	School aged- far right bathroom faucet	<1.0	<1.0	N/A
1-1-2S-BF2	2s middle bathroom faucet	<1.0	<1.0	N/A
1-1-2S-BF3	2s far left bathroom faucet	<1.0	<1.0	N/A
1-1-INF-CF1	Infant- single white classroom faucet	<1.0	<1.0	N/A
1-1-PREK-CF1	Pre-K- single white classroom faucet	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-2S-BF1	2s far right bathroom faucet	1.1	<1.0	