



## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - Blackwell Head Start & Early Head Start on August 7, 2025. Overall, sixteen (16) outlets were tested resulting in a total of thirty-two (32) samples being sent to the lab.

- Twenty-seven (27) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-MNT-WC1	Water cooler; 1 <sup>st</sup> building; maintenance room; Dispenser next to right hand faucet on back wall	<1.0	<1.0	N/A
1-1-BRK-BF1	Bathroom faucet; 1 <sup>st</sup> building; staff break room; Right faucet next to toilet	<1.0	<1.0	N/A
1-1-BRK-CF1	Classroom faucet; 1 <sup>st</sup> building; staff break room; faucet outside of bathroom	<1.0	<1.0	N/A
1-1-EHS1-CF1	Classroom faucet; 1 <sup>st</sup> building; Early Head Start Room 1; faucet outside of bathroom	<1.0	<1.0	N/A
1-1-EHS1-BF1	Bathroom faucet; 1 <sup>st</sup> building; Early Head Start Room 1; left faucet	<1.0	<1.0	N/A
1-1-BATH-BF1	Bathroom faucet; 1 <sup>st</sup> building; Bathroom	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet; 1 <sup>st</sup> building; kitchen; silver faucet on right of single compartment sink	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet; 1 <sup>st</sup> building; kitchen; faucet in 3 compartment sink	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw ( $\mu\text{g/L}$ )	Flush ( $\mu\text{g/L}$ )	Remedial Action
		Initial Sampling		
1-1-EHS2-CF1	Classroom faucet; 1 <sup>st</sup> building; Early Head Start Room 2; faucet outside of bathroom	<1.0	<1.0	N/A
1-1-EHS2-BF1	Bathroom faucet; 1 <sup>st</sup> building; Early Head Start Room 2; Bathroom faucet on left	<1.0	<1.0	N/A
2-1-HS-CF1	Classroom faucet; 2 <sup>nd</sup> building; Head Start Room; faucet outside bathroom	<1.0	<1.0	N/A
2-1-HS-BF1	Bathroom faucet; 2 <sup>nd</sup> building; Head Start Room; faucet on right	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 <math>\mu\text{g/L}</math>)</b>				
1-1-MNT-CF1	Classroom faucet; 1 <sup>st</sup> building; maintenance room; right side faucet	<1.0	1.1	
1-1-EHS2-BF2	Bathroom faucet; 1 <sup>st</sup> building; Early Head Start Room 2; faucet on right	1.2	<1.0	
1-1-HS-BF1	Bathroom faucet; 1 <sup>st</sup> building; Head Start Room; faucet on left	1.7	<1.0	
1-1-MNT-BF1	Bathroom faucet; 1 <sup>st</sup> building; maintenance room; left faucet next to toilet	2.4	1.9	
<b>NOT SAMPLED</b>				
1-1-EHS1-BF2	Bathroom faucet; 1 <sup>st</sup> building; Early Head Start Room 1; right faucet	Not Sampled	Not Sampled	