



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Building Blocks for Higher Learning

School: Building Blocks for Higher Learning

Sampling Date: 6/3/2025

Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Building Blocks for Higher Learning – Building Blocks for Higher Learning on June 3, 2025. Overall, six (6) outlets were tested resulting in a total of twelve (12) samples being sent to the lab.

- Eleven (11) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen faucet in Orange Room	<1.0	<1.0	N/A
1-1-OR-CF1	Classroom faucet in Orange Room	<1.0	<1.0	N/A
1-1-BR-BF1	Bathroom faucet in Orange Room	<1.0	<1.0	N/A
1-1-YR-CF1	Classroom faucet in Yellow Room	<1.0	<1.0	N/A
1-1-GR-CF1	Classroom faucet in Green Room	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-GR-BF1	Bathroom faucet in Green Room	<1.0	1.3	