



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Save the Children Head Start

School: Carl Albert State College

Sampling Date: 6/27/2025

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Save the Children Head Start - Carl Albert State College on June 27, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Two (2) samples had no detectable level of lead.
- Twelve (12) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen- two compartment sink faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-EHS1-CF1	First infant room near kitchen- classroom faucet	1.6	1.2	Handwash Only
1-1-EHS1-CF3	Second infant room connected to first-classroom faucet	2.0	1.0	Handwash Only
1-1-KB-BF3	Kids bathroom- far right faucet	2.6	1.1	Handwash Only
1-1-KB-BF2	Kids bathroom- middle faucet	2.7	1.4	Handwash Only
1-1-EHS1-CF2	First infant room near kitchen- sprayer	4.2	1.4	Handwash Only
1-1-KB-BF1	Kids bathroom- far left faucet	6.1	5.8	Handwash Only