



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of OKC

School: Carolyn Shaw Head Start

Sampling Dates: 8/20/2024, 7/30/2025

Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of OKC - Carolyn Shaw Head Start. The initial sampling event occurred on August 20, 2024. The resampling event occurred on July 30, 2025.

In the initial sampling, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Seven (7) samples had no detectable level of lead.
- Thirteen (13) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Two (2) samples had no detectable level of lead.
- Twelve (12) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-HALL-WC1	Elkay bottle filler in main hallway	<1.0	<1.0	N/A		
1-1-HALL-WC2	Elkay water cooler in main hallway	<1.0	<1.0	N/A		
1-1-KIT-IM1	Manitowoc ice machine in facility kitchen; brass-looking filter valve	<1.0	<1.0	N/A		
Low Detection (1.0 - 14.9 µg/L)						
1-1-BR-BF2	Bathroom faucet in boys' bathroom; right side	1.5	1.2		2.1	1.9
1-1-BR-BF1	Bathroom faucet in boys' bathroom; left side	3.7	1.9		2.4	1.3
1-1-GR-BF1	Bathroom faucet in girls' restroom; left side	1.8	1.1		2.4	2.0

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-GR-BF2	Bathroom faucet in girls' restroom; right side	<1.0	1.3		2.7	1.3
1-1-1-CF1	Classroom faucet in Classroom 1; right side	8.7	1.9		8.6	<1.0
1-1-1-CF2	Classroom faucet in Classroom 1; left side	10.7	2.0		9.5	<1.0
1-1-2-CF1	Classroom faucet in Classroom 2	3.7	1.3		13.8	1.3