



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Children's Lighthouse

School: Children's Lighthouse I

Sampling Date: 6/12/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Children's Lighthouse - Children's Lighthouse I on June 12, 2025. Overall, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- All two (2) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as $\mu\text{g/L}$. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw ($\mu\text{g/L}$)	Flush ($\mu\text{g/L}$)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 $\mu\text{g/L}$)				
1-1-KIT-KF1	Kitchen Pot filler	<1.0	<1.0	N/A