



OKLAHOMA DRINKING WATER
LEAD TESTING
 IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Children’s Lighthouse District
 School: Children’s Lighthouse III
 Sampling Date: 6/12/2025
 Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Children’s Lighthouse District - Children’s Lighthouse III on June 12, 2025. Overall, fourteen (14) outlets were tested resulting in a total of twenty-eight (28) samples being sent to the lab.

- Eleven (11) samples had no detectable level of lead.
- Sixteen (16) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- One (1) sample had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen industrial kitchen faucet closest to door	<1.0	<1.0	N/A
1-1-IN-CF1	Infant room- classroom faucet in first room on back wall	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-MM-CF1	Mickey Mouse room- far left faucet when entering room	1.0	<1.0	
1-1-MM-BF1	Mickey Mouse room -far right faucet	1.0	<1.0	
1-1-4YR-BF1	Bathroom faucet in 4-year-old area	1.5	<1.0	
1-1-4YR-CF1	Classroom faucet in 4s room	1.5	<1.0	
1-1-3YR-BF1	Bathroom faucet in 3yr room	1.7	<1.0	
1-1-KIT-KF2	Kitchen- left faucet closest to back wall	3.2	<1.0	
1-1-TOD-CF1	Toddler room- far left classroom faucet	4.6	<1.0	
1-1-2YRS-BF2	2 yr old bathroom faucet closest to front door	5.4	3.4	
1-1-2YRS-BF1	2 yr old room bathroom faucet	2.3	6.3	
1-1-2YRS-CF1	2 yr old room far left classroom faucet	6.6	10.2	
1-1-3YR-CF1	Classroom faucet in 3yr area	12.7	1.4	

Sample ID	Outlet Description	First Draw ($\mu\text{g/L}$)	Flush ($\mu\text{g/L}$)	Remedial Action
		Initial Sampling		
High Detection ($\geq 15.0 \mu\text{g/L}$)				
1-1-2YRS-DW1	2 yr old room right classroom faucet	6.6	21.3	