



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Enid Public SchoolsSchool: Coolidge Elementary SchoolSampling Dates: 3/24/2023, 6/25/2025Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Enid Public Schools - Coolidge Elementary School. The initial sampling event occurred on March 24, 2023. The resampling event occurred on June 25, 2025.

In the initial sampling, eighteen (18) outlets were tested resulting in a total of thirty-six (36) samples being sent to the lab.

- Twenty-eight (28) samples had no detectable level of lead.
- Eight (8) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, six (6) outlets were tested resulting in a total of twelve (12) samples being sent to the lab.

- Zero (0) samples had no detectable level of lead.
- Twelve (12) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-HALL-WC1	Elkay water cooler; left side; near front entrance and offices; between faculty work room and Room 42	<1.0	<1.0	N/A		
1-1-HALL-WC2	Elkay water cooler; right side; near front entrance and offices; between faculty work room and Room 42	<1.0	<1.0	N/A		
1-1-HALL-WC3	Elkay water cooler; left side; classroom additions; between Room 22 and boys' restroom	<1.0	<1.0	N/A		
1-1-HALL-WC4	Elkay water cooler; right side; classroom additions; between Room 22 and boys' restroom	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-HALL-WC5	Oasis bottle filler; classroom additions; between Room 22 and boys' restroom	<1.0	<1.0	N/A		
1-1-HALL-WC6	Elkay water cooler; left side; Pre-K classrooms; between Rooms 11 and 13 near boys' restroom	<1.0	<1.0	N/A		
1-1-HALL-WC7	Elkay water cooler; right side; Pre-K classrooms; between Rooms 11 and 13 near boys' restroom	<1.0	<1.0	N/A		
2-1-HALL-WC3	Elkay water cooler; left side; between Rooms 7 and 8	<1.0	<1.0	N/A		
2-1-HALL-WC4	Elkay water cooler; right side; between Rooms 7 and 8	<1.0	<1.0	N/A		
2-1-HALL-WC6	Elkay water cooler; left side; outside of gym	<1.0	<1.0	N/A		
2-1-HALL-WC7	Elkay water cooler; right side; outside of gym	<1.0	<1.0	N/A		
Low Detection (1.0 - 14.9 µg/L)						
1-1-HALL-WC10	Oasis bottle filler between bathrooms behind cafeteria	1.0	<1.0		Unable to be sampled	
2-1-HALL-WC2	Elkay water cooler; right side; near Rooms 2 and 3	1.2	<1.0		2.0	1.4
2-1-HALL-WC1	Elkay water cooler; left side; near Rooms 2 and 3	1.2	1.0		1.9	2.2
2-1-HALL-WC5	Oasis bottle filler between Rooms 7 and 8	1.1	<1.0		1.9	2.3
1-1-HALL-WC8	Elkay water cooler; left side; between bathrooms behind cafeteria	<1.0	1.1		2.4	1.0
1-1-HALL-WC9	Elkay water cooler; right side; between bathrooms behind cafeteria	<1.0	1.1		3.8	1.8
2-1-TL-KF	Kitchen faucet in teachers' lounge (Room 10)	3.4	<1.0		8.7	1.6