



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Crescent School District
School: Crescent Elementary School
Sampling Date: 6/25/2025
Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Crescent School District – Crescent Elementary School on June 25, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- All fourteen (14) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-ENT-WC1	Front entrance- left fountain in front entrance (taller)	<1.0	<1.0	N/A
1-1-ENT-WC2	Front entrance- Bottle filler	<1.0	<1.0	N/A
1-1-ENT-WC3	Front entrance- Right fountain lower	<1.0	<1.0	N/A
1-1-HALL-WC1	Hall next to 4012- left fountain taller	<1.0	<1.0	N/A
1-1-HALL-WC2	Hall next to 4012- bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC3	Hall next to 4012- right fountain lower	<1.0	<1.0	N/A
1-1-G.ENT-WC1	Gym entryway water cooler	<1.0	<1.0	N/A