



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Crescent School District

School: Crescent High School

Sampling Date: 6/25/2025

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Crescent School District – Crescent High School on June 25, 2025. Overall, fifteen (15) outlets were tested resulting in a total of thirty (30) samples being sent to the lab.

- Twenty-three (23) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Two (2) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Hall across from room 3 - bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC2	Hall across from room 3 - water cooler	<1.0	<1.0	N/A
1-1-HALL-WC3	Hall across from room 8 - bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC4	Hall across from room 8 - water cooler	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen front section sink	<1.0	<1.0	N/A
2-1-CAF-WC1	Cafeteria water cooler right side of entrance, left higher	<1.0	<1.0	N/A
2-1-CAF-WC2	Cafeteria water cooler right side of entrance, bottle filler	<1.0	<1.0	N/A
2-1-CAF-WC3	Cafeteria water cooler right side of entrance, right lower	<1.0	<1.0	N/A
2-1-CAF-WC4	Cafeteria water cooler left side of entrance, left higher	<1.0	<1.0	N/A
2-1-CAF-WC5	Cafeteria water cooler left side of entrance, bottle filler	<1.0	<1.0	N/A
2-1-CAF-WC6	Cafeteria water cooler left side of entrance, right lower	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Low Detection (1.0 - 14.9 µg/L)				
2-1-KIT-KF1	Kitchen back section sink	4.4	<1.0	
1-1-8-KF2	Kitchen back left sink	12.0	2.5	Filter added
High Detection (≥15.0 µg/L)				
1-1-8-KF3	Kitchen back right sink	15.0	2.1	Filter added
1-1-8-KF1	Kitchen front sink	22.1	3.7	Filter added