



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Crescent School District

School: Crescent Middle School

Sampling Date: 6/25/2025

Status: Complete

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Crescent School District – Crescent Middle School on June 25, 2025. Overall, three (3) outlets were tested resulting in a total of six (6) samples being sent to the lab.

- Four (4) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC2	HALL bottle filler	<1.0	<1.0	N/A
1-1-HALL-WC3	HALL fountain below bottle filler	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-HALL-WC1	HALL fountain left of bottle filler	1.7	1.9	Removed from service