



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Childcare center
School: Cuddles and Crayons-West
Sampling Date: 7/17/2025
Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Childcare center – Cuddles and Crayons-West on July 17, 2025. Overall, seven (7) outlets were tested resulting in a total of fourteen (14) samples being sent to the lab.

- Fourteen (13) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen- three compartment sink faucet	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen- single compartment sink right of three compartment sink	<1.0	<1.0	N/A
1-1-1R-CF1	One's room classroom faucet	<1.0	<1.0	N/A
1-1-2R-CF1	Two's room classroom faucet	<1.0	<1.0	N/A
1-1-PRE-CF1	Preschool classroom faucet	<1.0	<1.0	N/A
1-1-INF-CF1	First infant room classroom faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-INF-CF2	Second infant room (in back) classroom faucet	3.1	<1.0	