



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: UCAP, Inc.  
School: Cushing Head Start  
Sampling Date: 8/5/2025  
Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. – Cushing Head Start on August 5, 2025. Overall, nine (9) outlets were tested resulting in a total of eighteen (18) samples being sent to the lab.

- Fifteen (15) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-PAN-WC1	Water cooler; Pantry; Brio water dispenser	<1.0	<1.0	N/A
1-1-HS1-BF1	Bathroom faucet; Head Start Room 1; left faucet	<1.0	<1.0	N/A
1-1-HS1-BF2	Bathroom faucet; Head Start Room 1; right faucet	<1.0	<1.0	N/A
1-1-EHS-CF1	Classroom faucet; Early Head Start Room; silver faucet on right side wall	<1.0	<1.0	N/A
1-1-EHS-CF2	Classroom faucet; Early Head Start room; white faucet on right side wall	<1.0	<1.0	N/A
1-1-BR-BF1	Bathroom faucet; bathroom outside of Early Head Start room; only white faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet; kitchen; faucet in 2 compartment sink	<1.0	1.8	
1-1-KIT-KF2	Kitchen faucet; kitchen; sprayer in 2 compartment sink	1.2	<1.0	
1-1-EHS-BF1	Bathroom faucet; bathroom inside Early Head Start Room; white faucet	2.6	<1.0	