



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of Oklahoma CitySchool: Dana Brown Cooper Head StartSampling Dates: 10/27/2023, 6/11/2025Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of Oklahoma City – Dana Brown Cooper Head Start. The initial sampling event occurred on October 27, 2023. The resampling event occurred on June 11, 2025.

In the initial sampling, sixteen (16) outlets were tested resulting in a total of thirty-two (32) samples being sent to the lab.

- Twenty-six (26) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Five (5) samples had no detectable level of lead.
- Five (5) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-TL-IM1	Teacher's Lounge Ice Machine	<1.0	<1.0	-	-	-
1-1-TL-KF1	Teacher's Lounge kitchen faucet	<1.0	<1.0	-	-	-
1-1-ABATH-BF1	Classroom A bathroom faucet right	<1.0	<1.0	-	-	-
1-1-ABATH-BF2	Classroom A bathroom faucet left	<1.0	<1.0	-	-	-
1-1-ABATH-CF1	Classroom A classroom faucet	<1.0	<1.0	-	-	-
1-1-KIT-KF2	Kitchen faucet left of door	<1.0	<1.0	-	-	-
1-1-HALL-WC2	Hall near kitchen water cooler	<1.0	<1.0	-	-	-

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-C-CF1	Classroom C classroom faucet	<1.0	<1.0	-	-	-
1-1-B&C-BF1	Bathroom between B&C classroom- right side bathroom faucet	<1.0	<1.0	-	-	-
1-1-B&C-BF2	Bathroom between B&C classroom- left side bathroom faucet	<1.0	<1.0	-	-	-
1-1-B-CF1	Classroom B classroom faucet	<1.0	<1.0	-	-	-
1-1-KIT-KF1	Kitchen faucet right of door	1.1	<1.0		<1.0	<1.0
Low Detection (1.0 - 14.9 µg/L)						
1-1-HALL-WC1	Hall outside of teachers' lounge - water cooler	5.9	<1.0		1.3	<1.0
1-1-HALL-WC3	Hall by back breezeway- water cooler	2.4	1.9		3.6	3.5
1-1-OUT-DW1	Outside in playground drinking fountain	2.5	<1.0		4.6	<1.0
1-1-KIT-KF3	Kitchen back left corner- 3 compartment sink faucet	1.1	<1.0		6.9	<1.0