



OKLAHOMA DRINKING WATER
LEAD TESTING
IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Child Care Center
School: Dimples & Smiles Daycare
Sampling Date: 7/2/2025
Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Child Care Center - Dimples & Smiles Daycare on July 2, 2025. Overall, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- Zero (0) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID | Outlet Description | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|---------------------------------|--------------------|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| Low Detection (1.0 - 14.9 µg/L) | | | | |
| 1-1-KIT-KF1 | Kitchen faucet | 3.8 | 3.0 | |