



RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Sunbeam Family Services - Edwards Early Education Center. The initial sampling event occurred on January 12, 2024. The first resampling event occurred on May 17, 2024. The second resampling event occurred on July 29, 2025.

In the initial sampling, seventy-six (76) outlets were tested resulting in a total of one hundred fifty-two (152) samples being sent to the lab.

- Eighty-nine (89) samples had no detectable level of lead.
- Fifty-three (53) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Ten (10) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, eighteen (18) outlets were tested resulting in a total of thirty-six (36) samples being sent to the lab.

- Eleven (11) samples had no detectable level of lead.
- Twenty (20) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Five (5) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Eleven (11) samples had no detectable level of lead.
- Nine (9) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling 1		Resampling 2	
Non-Detect (<1.0 µg/L)								
1-1-C109-BF	Bathroom faucet in Room C109 bathroom	<1.0	<1.0	N/A				
1-1-C109-CF3	Short handwash faucet in Room C109	<1.0	<1.0	N/A				
1-1-C105-CF3	Short handwash faucet in Room C105	<1.0	<1.0	N/A				

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling 1		Resampling 2	
1-1-C107-BF	Bathroom faucet in Room C107 bathroom	<1.0	<1.0	N/A				
1-1-C107-CF3	Short handwash faucet in Room C107	<1.0	<1.0	N/A				
1-1-C102-CF3	Short handwash faucet in Room C102	<1.0	<1.0	N/A				
1-1-A103-IM1	Ice machine in Room A103	<1.0	<1.0	N/A				
1-1-A103-IM2	Drinking water dispenser attached to ice machine in Room A103	<1.0	<1.0	N/A				
1-1-A104-CF1	Left tall handwash faucet in Room A104	<1.0	<1.0	N/A				
1-1-A104-CF2	Right tall handwash faucet in Room A104	<1.0	<1.0	N/A				
1-1-A104-CF3	Short handwash faucet in Room A104	<1.0	<1.0	N/A				
1-1-A107-CF1	Left tall handwash faucet in Room A107	<1.0	<1.0	N/A				
1-1-A107-CF2	Right tall handwash faucet in Room A107	<1.0	<1.0	N/A				
1-1-A107-CF3	Short handwash faucet in Room A107	<1.0	<1.0	N/A				
1-1-A111-CF1	Left tall handwash faucet in Room A111	<1.0	<1.0	N/A				
1-1-A111-CF2	Right tall handwash faucet in Room A111	<1.0	<1.0	N/A				
1-1-A112-IM	Ice machine in Room A112	<1.0	<1.0	N/A				
1-1-HALL-WC2	Elkay water cooler; between Rooms A111 and A113	<1.0	<1.0	N/A				
1-1-A113-CF2	Right tall handwash faucet in Room A113	<1.0	<1.0	N/A				
1-1-A113-CF3	Short handwash faucet in Room A113	<1.0	<1.0	N/A				
1-1-A114-CF1	Left tall handwash faucet in Room A114	<1.0	<1.0	N/A				
1-1-A114-CF2	Right tall handwash faucet in Room A114	<1.0	<1.0	N/A				

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling 1		Resampling 2	
1-1-A114-CF3	Short handwash faucet in Room A114	<1.0	<1.0	N/A				
1-1-C115-CF3	Short handwash faucet in Room C115	<1.0	<1.0	N/A				
2-1-HALL-WC1	Add-on building; Elkay water cooler; left side; At hallway intersection	<1.0	<1.0	N/A				
2-1-HALL-WC2	Add-on building; Elkay water cooler; right side; At hallway intersection,	<1.0	<1.0	N/A				
3-1-HALL-WC1	Elkay water cooler; left side; Next to bathroom in gym	<1.0	<1.0	N/A				
3-1-HALL-WC2	Elkay water cooler; right side; Next to bathroom in gym	<1.0	<1.0	N/A				
3-1-G103-KF	Kitchen handwash faucet in Room G103	<1.0	<1.0	N/A				
3-1-G103-IM1	Ice machine in Room G103	<1.0	<1.0	N/A				
3-1-G103-IM2	Drinking water dispenser attached to ice machine in Room G103	<1.0	<1.0	N/A				
1-1-C109-CF1	Left tall handwash faucet in Room C109	8.0	4.7	Flush	<1.0	<1.0		
1-1-C109-CF2	Right tall handwash faucet in Room C109	21.1	1.8	Flush	<1.0	<1.0	<1.0	<1.0
1-1-C112-CF1	Left tall handwash faucet in Room C112	32.6	5.2	Flush	17.2	4.1	<1.0	<1.0
1-1-C107-CF1	Left tall handwash faucet in Room C107	46.9	6.9	Flush	3.0	<1.0	<1.0	<1.0
Low Detection (1.0 - 14.9 µg/L)								
1-1-C108-CF3	Short handwash faucet in Room C108	<1.0	1.1					
1-1-C102-BF	Bathroom faucet in Room C102 bathroom	<1.0	1.2					
1-1-A111-CF3	Short handwash faucet in Room A111	<1.0	1.9					
1-1-A113-CF1	Left tall handwash faucet in Room A113	1.0	<1.0					

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling 1		Resampling 2	
2-1-E107-CF1	Add-on Building; Handwash faucet in Room E107	1.0	<1.0					
1-1-A112-KF	Large dishwashing faucet in Room A112	1.1	<1.0					
1-1-A107-BF	Bathroom faucet in Room A107 bathroom	1.5	<1.0					
1-1-HALL-WC1	Elkay water cooler; Between Rooms C105 and C108	1.5	1.8					
1-1-C112-BF	Bathroom faucet in Room C112 bathroom	57.6	3.9	Flush	29.4	7.1	1.5	<1.0
1-1-A104-BF	Bathroom faucet in Room A104 bathroom	1.6	<1.0					
1-1-A114-BF	Bathroom faucet in Room A114 bathroom	1.6	<1.0					
2-1-E107-CF2	Drinking water bubbler in Room E107	1.6	<1.0					
1-1-C107-CF2	Right tall handwash faucet in Room C107	53.9	7.1	Flush	5.0	1.8	1.6	<1.0
1-1-A115-KF	Handwash faucet in Room A115	1.7	<1.0					
1-1-A113-BF	Bathroom faucet in Room A113 bathroom	1.8	<1.0					
1-1-A111-BF	Bathroom faucet in Room A111 bathroom	1.9	<1.0					
2-1-E104-CF1	Add-on building; Handwash faucet in Room E104	1.9	<1.0					
1-1-C108-CF2	Right tall handwash faucet in Room C108	2.2	<1.0					
1-1-C112-CF3	Short handwash faucet in Room C112	2.2	<1.0					
1-1-C108-CF1	Left tall handwash faucet in Room C108	2.3	<1.0					
1-1-C115-BF	Bathroom faucet in Room C115 bathroom	2.5	<1.0					
2-1-E103-CF1	Add-on building; Handwash faucet in Room E103	2.7	<1.0					

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling 1		Resampling 2	
2-1-E105-CF1	Add-on building; Handwash faucet in Room E105	2.9	<1.0					
2-1-E104-CF2	Add-on building; Drinking water bubbler in Room E104	11.7	<1.0	Flush	3.0	<1.0		
2-1-C121-42I-CF	Add-on building; Backroom handwash faucet in Room C121/42I	3.1	<1.0					
1-1-C108-BF	Bathroom faucet in Room C108 bathroom	3.1	2.9					
2-1-E105-CF2	Add-on building; Drinking water bubbler in Room E105	3.2	<1.0					
2-1-E106-CF1	Add-on building; Handwash faucet in Room E106	3.2	<1.0					
1-1-C105-BF	Bathroom faucet in Room C105 bathroom	17.0	1.1	Flush	7.1	<1.0	3.2	<1.0
1-1-C105-CF1	Left tall handwash faucet in Room C105	5.4	1.8	Flush	14.0	1.6	3.3	<1.0
2-1-E102-CF1	Add-on building; Handwash faucet in Room E102	4.2	<1.0					
2-1-E102-CF2	Add-on building; Drinking water bubbler in Room E102	4.2	<1.0					
1-1-C103-KF	Kitchen handwash faucet in Room C103	5.4	1.3	Flush	4.3	<1.0		
2-1-E103-CF2	Add-on building; Drinking water bubbler in Room E103	11.0	<1.0	Flush	4.3	<1.0		
1-1-C115-CF1	Left tall handwash faucet in Room C115	4.5	<1.0					
2-1-E106-CF2	Add-on building; Drinking water bubbler in Room E106	16.2	<1.0	Flush	4.2	<1.0	5.6	<1.0
1-1-A103-KF	Kitchen handwash faucet in Room A103	5.9	1.6	Flush	7.2	2.4		
1-1-C112-CF2	Right tall handwash faucet in Room C112	6.9	3.0	Flush	7.3	<1.0		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling 1		Resampling 2	
1-1-C115- CF2	Right tall handwash faucet in Room C115	9.8	<1.0	Flush	9.4	1.2		
1-1-C102- CF2	Right tall handwash faucet in Room C102	42.0	6.9	Flush	21.4	3.3	10.2	1.6
1-1-C102- CF1	Left tall handwash faucet in Room C102	20.0	4.3	Flush	27.2	6.2	11.0	1.8
High Detection (≥15.0 µg/L)								
1-1-C105- CF2	Right tall handwash faucet in Room C105	18.9	2.5	Flush	18.9	2.8		