



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Flower Mound Public School District

School: Flower Mound Public School

Sampling Date: 6/4/2025

Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Flower Mound Public School District - Flower Mound Public School on June 4, 2025. Overall, fifteen (15) outlets were tested resulting in a total of thirty (30) samples being sent to the lab.

- Twenty-nine (29) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-NRC-CF1	North wing right classroom	<1.0	<1.0	N/A
1-1-NCB-BF1	North wing children's bathroom	<1.0	<1.0	N/A
1-1-HALL-WC1	In between men and women's bathrooms across from front office	<1.0	<1.0	N/A
1-1-NWB-BF1	Women's bathroom North wing	<1.0	<1.0	N/A
1-1-LB-BF1	Library bathroom	<1.0	<1.0	N/A
1-1-HALL-WC2	Bottle filling station to the right of library	<1.0	<1.0	N/A
1-1-HALL-WC3	Drinking fountain under bottle fill to the right of library	<1.0	<1.0	N/A
3-1-HALL-WC1	Bottle filling station between men and women's bathrooms	<1.0	<1.0	N/A
3-1-HALL-WC2	Drinking fountain under bottle filler in between men and women's bathrooms	<1.0	<1.0	N/A
3-1-KIT-KF1	Kitchen sprayer	<1.0	<1.0	N/A
3-1-KIT-KF2	Kitchen pot filler	<1.0	<1.0	N/A
3-1-KIT-KF3	Kitchen vegetable sink	<1.0	<1.0	N/A
4-1-PRC-WC1	Portable right classroom Water cooler	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
4-1-PRC-BF1	Right portable classroom bathroom faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
2-1-SB-BF1	Bathroom in portable single portable	1.4	<1.0	