



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Green Country Behavioral Health ServicesSchool: Ft. Gibson Head StartSampling Date: 7/18/2025Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Green Country Behavioral Health Services – Ft. Gibson Head Start on July 18, 2025. Overall, six (6) outlets were tested resulting in a total of twelve (12) samples being sent to the lab.

- Eleven (11) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-215-BF1	Room 215 - Small white bathroom faucet	<1.0	<1.0	N/A
1-1-215-CF1	Room 215 - small white classroom faucet	<1.0	<1.0	N/A
1-1-LOB-WC1	Lobby Bottle filler	<1.0	<1.0	N/A
1-1-LOB-WC2	Lobby Water cooler	<1.0	<1.0	N/A
1-1-216-CF1	Room 216 - small white classroom faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-216-BF1	Room 216 - small white bathroom faucet	<1.0	1.9	