



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Community Action Agency of OKC

School: Garden Diggs Head Start

Sampling Dates: 8/20/2024, 7/31/2025

Status: Remediation

RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of OKC - Garden Diggs Head Start. The initial sampling event occurred on August 20, 2024. The resampling event occurred on July 31, 2025.

In the initial sampling, eight (8) outlets were tested resulting in a total of sixteen (16) samples being sent to the lab.

- Ten (10) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, five (5) outlets were tested resulting in a total of [Insert samples ten (10) samples being sent to the lab.

- Four (4) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-BR-BF1	Bathroom faucet in boys' restroom; left side	<1.0	<1.0	N/A		
1-1-BR-BF2	Bathroom faucet in boys' restroom; right side	<1.0	<1.0	N/A		
1-1-KIT-KF2	Kitchen faucet in facility kitchen; double sink; left side	<1.0	<1.0	N/A		
Low Detection (1.0 - 14.9 µg/L)						
1-1-GR-BF2	Bathroom faucet in girls' restroom; right side	1.63	<1.0		1.0	<1.0
1-1-KIT-KF3	Kitchen faucet in facility kitchen; double sink; right side	1.42	<1.0		1.1	<1.0

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-KIT-KF1	Kitchen faucet in facility kitchen; standalone sink near door	2.08	<1.0		1.3	<1.0
1-1-GR-BF1	Bathroom faucet in girls' restroom; left side	5.29	<1.0		1.8	<1.0
1-1-A-WC1	Elkay water cooler in Classroom A	1.25	3.5		2.3	4.6