

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Geronimo Public Schools - Geronimo High School on September 19, 2025. Overall, thirteen (13) outlets were tested resulting in a total of twenty-six (26) samples being sent to the lab.

- Twenty-five (25) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF2	Kitchen faucet; kitchen; silver 2 compartment sink left wall from kitchen entrance	<1.0	<1.0	N/A
1-1-KIT-IM1	Ice machine; kitchen; right of fridges	<1.0	<1.0	N/A
1-1-CAF-WC1	Water cooler; cafeteria; far left set of water coolers closet to men's restroom; top left bottle filler	<1.0	<1.0	N/A
1-1-CAF-WC3	Water cooler; cafeteria; single middle water cooler between men's and women's restrooms	<1.0	<1.0	N/A
1-1-CAF-WC4	Water cooler; cafeteria; far right single water cooler between men's and women's restrooms	<1.0	<1.0	N/A
1-1-CAF-WC5	Water cooler; cafeteria; right set of water coolers to the right of women's restroom; left tall cooler	<1.0	<1.0	N/A
1-1-CAF-WC6	Water cooler; cafeteria; right set of water coolers to the right of women's restroom; last far right short cooler	<1.0	<1.0	N/A
1-1-GYM-WC1	Water cooler; gymnasium; left side stands right of Room 503 varsity women's room; middle tallest cooler	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-GYM-WC2	Water cooler; gymnasium; left side stands right of Room 503 varsity women's room; far right short cooler	<1.0	<1.0	N/A
1-1-GYM-WC3	Water cooler; gymnasium; right side of stands left of Room 507 JV women's room; far left top bottle filler	<1.0	<1.0	N/A
1-1-GYM-WC4	Water cooler; gymnasium; right side of stands left of Room 507 JV women's room; middle cooler	<1.0	<1.0	N/A
1-1-GYM-WC5	Water cooler; gymnasium; right side of stands left of Room 507 JV women's room; far right cooler	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet; kitchen; single white faucet right of silver 2 compartment sink	2.2	<1.0	

Not Sampled				
1-1-CAF-WC2	Water cooler; cafeteria; far left set of water coolers closet to men's restroom: bottom water cooler	N/A	N/A	