



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Child Care Centers

School: Goodnight-Moon Child Care

Sampling Date: 6/10/2025

Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Child Care Centers - Goodnight-Moon Child Care on June 10, 2025. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Seven (7) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID | Outlet Description | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|---------------------------------|---|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| Non-Detect (<1.0 µg/L) | | | | |
| 1-1-GRR-BF1 | Girls’ bathroom faucet closest to front door | <1.0 | <1.0 | N/A |
| 1-1-BRR-BF1 | Boys’ bathroom faucet closest to the right of the kitchen | <1.0 | <1.0 | N/A |
| Low Detection (1.0 - 14.9 µg/L) | | | | |
| 1-1-KIT-BF1 | Employee only bathroom faucet in kitchen | 1.4 | <1.0 | |
| 1-1-KIT-KF1 | Kitchen faucet under paper towels left of sanitize area | 3.0 | <1.0 | |
| 1-1-LR-KF1 | Laundry room/kitchen area faucet | 4.1 | <1.0 | |