



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Child Care Center
School: Auriel Green Daycare
Sampling Date: 7/30/2025
Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Child Care Center - Auriel Green Daycare on July 30, 2025. Overall, four (4) outlets were tested resulting in a total of eight (8) samples being sent to the lab.

- Four (4) samples had no detectable level of lead.
- Four (4) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID | Outlet Description | First Draw (µg/L) | Flush (µg/L) | Remedial Action |
|---------------------------------|---|----------------------|-----------------|-----------------|
| | | Initial Sampling | | |
| Low Detection (1.0 - 14.9 µg/L) | | | | |
| 1-1-KIT-KF1 | Kitchen faucet; 1 st floor; kitchen | 1.5 | <1.0 | |
| 1-2-MBR-BF1 | Bathroom faucet; 2 nd floor; master bathroom | 2.3 | <1.0 | |
| 1-2-UBR-BF1 | Bathroom faucet; 2 nd floor; bathroom right of stairs | 2.8 | <1.0 | |
| 1-1-BR-BF1 | Bathroom faucet; 1 st floor; bathroom connected to kitchen (half bath) | 4.3 | <1.0 | |