



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Childcare Facility
School: Green Country Child Care
Sampling Date: 7/18/2025
Status: Remediation

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Childcare Facility - Green Country Child Care on July 18, 2025. Overall, seventeen (17) outlets were tested resulting in a total of thirty-four (34) samples being sent to the lab.

- Twenty-five (25) samples had no detectable level of lead.
- Nine (9) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Hall between room 7-8 Elkay bottle filler	<1.0	<1.0	N/A
1-1-RM9-CF1	Room 9- right of door classroom faucet	<1.0	<1.0	N/A
1-1-HALL-WC2	Hall between room 9-10 Elkay bottle filler	<1.0	<1.0	N/A
1-1-RM10-CF1	Room 10- left wall classroom faucet	<1.0	<1.0	N/A
1-1-RM4-CF1	Room 4 left small white faucet	<1.0	<1.0	N/A
1-1-HALL-WC3	Hallway between lobby and restrooms bottle filler	<1.0	<1.0	N/A
1-1-RM1-CF1	Room 1 classroom faucet left back wall	<1.0	<1.0	N/A
1-1-RM2-CF1	Room 2 small white faucet, front right wall	<1.0	<1.0	N/A
1-1-RM1-BF1	Room 1 left corner white faucet in bathroom area	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-KIT-KF1	Kitchen faucet 2 compartment sink, right side wall	6.6	1.5	
1-1-KIT-IM1	Kitchen ice machine	1.3	<1.0	
1-1-RM4-CF2	Room 4 right tall silver faucet	1.4	<1.0	

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-KIT-KF2	Kitchen faucet 2 compartment sink under window	2.0	<1.0	
1-1-RM7-CF1	Room 7- back wall classroom faucet	2.4	<1.0	
1-1-RM2-CF2	Room 2 back right corner, silver faucet	2.7	<1.0	
1-1-RM8-CF1	Room 8-right back wall classroom faucet	3.6	<1.0	
1-1-RM5-CF1	Room 5 classroom faucet left front wall (drain clogged)	11.0	<1.0	