



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: UCAP Inc.  
School: Guthrie Early Head Start  
Sampling Date: 7/1/2025  
Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP Inc. - Guthrie Early Head Start on July 1, 2025. Overall, sixteen (16) outlets were tested resulting in a total of thirty-two (32) samples being sent to the lab.

- Fourteen (14) sample had no detectable level of lead.
- Eighteen (18) samples had a low detection of lead between 1.0 and 14.9 micrograms per Liter (ug/L).
- Zero (0) samples had a high detection of lead equal to or above 15.0 micrograms per Liter (ug/L).

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

| Sample ID                       | Outlet Description  | First Draw<br>(µg/L) | Flush<br>(µg/L) | Remedial Action |
|---------------------------------|---|----------------------|-----------------|-----------------|
|                                 |   | Initial Sampling     |                 |                 |
| Non-Detect (<1.0 µg/L)          |   |                      |                 |                 |
| 1-1-TL-WC1                      | Water cooler in teacher's lounge connected to kitchen                     | <1.0                 | <1.0            | N/A             |
| Low Detection (1.0 - 14.9 µg/L) |   |                      |                 |                 |
| 1-1-EHS2-CF3                    | Early Head Start Room 2; Sprayer connected to outlet #1                   | 1.0                  | <1.0            |                 |
| 1-1-EHS2-CF2                    | Early Head Start Room 2; Classroom faucet; Bottom secondary sink for kids | 1.0                  | <1.0            |                 |
| 1-1-EHS2-CF1                    | Early Head Start Room 2; Classroom faucet; Tall faucet                    | 1.1                  | <1.0            |                 |
| 1-1-KIT-KF2                     | Kitchen; Sprayer in 3 compartment sink                                    | 1.1                  | <1.0            |                 |
| 1-1-KIT-KF1                     | Kitchen; Kitchen faucet in 3 compartment sink                             | 1.3                  | <1.0            |                 |
| 1-1-HS2-CF2                     | Head Start Room 2; Sprayer connected faucet #4 in classroom               | 1.4                  | <1.0            |                 |
| 1-1-EHS1-CF2                    | Early Head Start Room 1; Sprayer connected to tall faucet                 | 1.5                  | 1.2             |                 |
| 1-1-EHS1-CF3                    | Early Head Start Room 1; Classroom faucet; Short faucet                   | 1.5                  | <1.0            |                 |

| Sample ID    | Outlet Description   | First Draw<br>(µg/L) | Flush<br>(µg/L) | Remedial<br>Action |
|--------------|--|----------------------|-----------------|--------------------|
|              |  | Initial Sampling     |                 |                    |
| 1-1-HS2-CF1  | Head Start Room 2 for 4-5 year olds;<br>Classroom faucet right of door; Only<br>faucet | 1.5                  | <1.0            |                    |
| 1-1-KIT-KF3  | Kitchen; Kitchen faucet left of 3<br>compartment sink                                  | 1.8                  | <1.0            |                    |
| 1-1-DO-CF1   | Director's office; Classroom faucet on<br>left wall                                    | 1.9                  | 1.2             |                    |
| 1-1-EHS1-CF1 | Early Head Start Room 1; Tall faucet<br>right of door                                  | 2.4                  | <1.0            |                    |
| 1-1-HS1-CF1  | Head Start Room 1 for 3-5 year olds;<br>Classroom faucet; Only faucet                  | 2.7                  | <1.0            |                    |
| 1-1-HS3-CF2  | Head Start Room 3; Classroom faucet;<br>Right faucet                                   | 6.5                  | <1.0            |                    |
| 1-1-HS3-CF1  | Head Start Room 3; Classroom faucet;<br>Left faucet closest to door                    | 7.6                  | 1.1             |                    |