



RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Lindsey Asher Partnerships - Happy Hands Educational Center for the Deaf on July 11, 2025. Overall, twenty-two (22) outlets were tested resulting in a total of forty-four (44) samples being sent to the lab.

- Forty-two (42) samples had no detectable level of lead.
- Two (2) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-HALL-WC1	Water cooler; hall across from room p01; water dispenser on the left	<1.0	<1.0	N/A
1-1-HALL-WC2	Water cooler hall across from room p01; water dispenser on the right	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet; kitchen; faucet in single compartment sink on right wall next to ice machine	<1.0	<1.0	N/A
1-1-KIT-IM1	Ice machine; kitchen	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen faucet; kitchen; faucet in 2 compartment in middle island	<1.0	<1.0	N/A
1-1-KIT-KF3	Kitchen faucet; kitchen; left faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-KIT-KF4	Kitchen faucet; kitchen; right faucet in 3 compartment sink	<1.0	<1.0	N/A
1-1-GOLD-CF1	Classroom faucet; goldfish room	<1.0	<1.0	N/A
1-1-WHITE-CF1	Classroom faucet; white room; tall left faucet	<1.0	<1.0	N/A
1-1-WHITE-CF2	Classroom faucet; white room; right short faucet	<1.0	<1.0	N/A

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
1-1-PRPL-CF1	Classroom faucet; purple cat room; tall right faucet	<1.0	<1.0	N/A
1-1-PRPL-CF1	Classroom faucet; purple cat room; left short faucet	<1.0	<1.0	N/A
1-1-TL-KF1	Kitchen faucet; kitchen area in teachers' lounge; only faucet	<1.0	<1.0	N/A
1-1-BLUE-CF1	Classroom faucet; blue horse room; left tall faucet	<1.0	<1.0	N/A
1-1-BLUE-CF2	Classroom faucet; blue horse room; right short faucet	<1.0	<1.0	N/A
1-1-GREEN-CF1	Classroom faucet; green frog room; right tall faucet	<1.0	<1.0	N/A
1-1-KITN-KF1	Kitchen faucet; kitchen area between red bird and yellow duck room	<1.0	<1.0	N/A
1-1-KITN-KF2	Kitchen faucet; kitchen area between red bird and yellow duck rooms; faucet under microwave in smaller compartment sink	<1.0	<1.0	N/A
1-1-RED-CF1	Classroom faucet; red bird room; right short faucet	<1.0	<1.0	N/A
1-1-RED-CF2	Classroom faucet; red bird room; left tall faucet	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-CON-CF1	Classroom faucet; conference room	1.0	<1.0	
1-1-GREEN-CF2	Classroom faucet; green frog room; left short faucet	1.7	<1.0	