



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Muskogee County Head Start

School: Haskell Head Start

Sampling Date: 7/17/2025

Status: Remediation

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Muskogee County Head Start - Haskell Head Start on July 17, 2025. Overall, five (5) outlets were tested resulting in a total of ten (10) samples being sent to the lab.

- Two (2) samples had no detectable level of lead.
- Eight (8) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
<b>Non-Detect (&lt;1.0 µg/L)</b>				
1-1-HALL-WC1	Hall; water cooler; water dispenser left of Early Head Start	<1.0	<1.0	N/A
<b>Low Detection (1.0 - 14.9 µg/L)</b>				
1-1-TL-KF1	Kitchen in teachers' lounge; kitchen faucet	3.8	1.2	
1-1-EHS-BF1	Early Head Start Classroom; bathroom faucet	5.3	1.3	
1-1-EHS-CF1	Early Head Start Classroom; classroom faucet; left faucet	5.4	1.5	
1-1-EHS-CF2	Early Head Start Classroom; classroom faucet; right faucet	8.0	2.4	