



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: UCAP, Inc.School: Henryetta Head Start & Early Head StartSampling Date: 6/25/2025Status: Completed Sampling

RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at UCAP, Inc. - Henryetta Head Start & Early Head Start on June 25, 2025. Overall, nine (9) outlets were tested resulting in a total of eighteen (18) samples being sent to the lab.

- All eighteen (18) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-KIT-KF1	Kitchen; Kitchen faucet in 2 bay sink	<1.0	<1.0	N/A
1-1-KIT-KF2	Kitchen; Kitchen faucet in 3 bay sink	<1.0	<1.0	N/A
1-1-HS-CF1	Head Start 3-5 Years Old Room; Classroom faucet	<1.0	<1.0	N/A
1-1-HS-BF1	Bathroom in Head Start 3-5 Years Old Room; Bathroom faucet	<1.0	<1.0	N/A
1-1-EHS2-CF1	Early Head Start Infants Room; Classroom faucet	<1.0	<1.0	N/A
1-1-EHS2-BF1	Bathroom in Early Head Start Infants Room; Bathroom faucet	<1.0	<1.0	N/A
1-1-HALL-WC1	Hallway; Water cooler; Water dispenser	<1.0	<1.0	N/A
1-1-EHS1-CF1	Early Head Start Room No. 1; Classroom faucet	<1.0	<1.0	N/A
1-1-EHS1-BF1	Bathroom in Early Head Start Room No. 1; Bathroom faucet	<1.0	<1.0	N/A