



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Big Five Community Services

School: Holdenville Head Start

Sampling Date: 10/11/2024

Status: Completed Sampling

## RESULTS

Below are the results from the first round of testing of drinking water for lead that was conducted at Big Five Community Services - Holdenville Head Start on October 11, 2024. Overall, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Nineteen (19) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action
		Initial Sampling		
Non-Detect (<1.0 µg/L)				
1-1-DAY-CF1	extended day sink	<1.0	<1.0	N/A
1-1-RM2-CF1	Room 2, classroom faucet	<1.0	<1.0	N/A
1-1-RM2-BF1	Room 2, bathroom sink	<1.0	<1.0	N/A
1-1-RM1-CF1	Room 1, classroom faucet short	<1.0	<1.0	N/A
1-1-RM1-DW1	Room 1, drinking water bubbler	<1.0	<1.0	N/A
1-1-RM1-BF1	Room 1, bathroom sink	<1.0	<1.0	N/A
1-1-KIT-KF1	Kitchen faucet	<1.0	<1.0	N/A
1-1-KIT -KF1	kitchen sprayer	<1.0	<1.0	N/A
1-1-KIT-IM1	kitchen ice machine	<1.0	<1.0	N/A
Low Detection (1.0 - 14.9 µg/L)				
1-1-TL-KF1	Staff Room kitchen faucet	2.0	<1.0	