



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

District: Southwest Oklahoma Community Action Agency

School: June Bailey Head Start

Sampling Dates: 6/26/2024, 6/18/2025

Status: Remediation

## RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Southwest Oklahoma Community Action Agency - June Bailey Head Start. The initial sampling event occurred on June 26, 2024. The resampling event occurred on June 18, 2025.

In the initial sampling, ten (10) outlets were tested resulting in a total of twenty (20) samples being sent to the lab.

- Eleven (11) samples had no detectable level of lead.
- Six (6) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Three (3) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, nine (9) outlets were tested resulting in a total of eighteen (18) samples being sent to the lab.

- Fifteen (15) samples had no detectable level of lead.
- Three (3) samples had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-KIT-KF1	Kitchen faucet in facility kitchen	<1.0	<1.0	N/A	<1.0	<1.0
1-1-RR-BF2	Bathroom faucet in larger bathroom; tall sink	<1.0	<1.0	N/A	<1.0	<1.0
1-1-3-BF1	Bathroom faucet in Room 3 classroom; used for brushing teeth	<1.0	<1.0	N/A	<1.0	<1.0
1-1-RR-BF1	Bathroom faucet in larger bathroom; short sink	1.2	<1.0		<1.0	<1.0
1-1-RR-BF3	Bathroom faucet in small bathroom for little children	1.2	<1.0		<1.0	<1.0

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-1-3-KF1	Kitchen faucet in Room 3 classroom	2.4	<1.0		<1.0	<1.0
1-1-HALL-WC1	Elkay water cooler in hall outside of conference room	8.1	19.4	REMOVED	N/A	
Low Detection (1.0 - 14.9 µg/L)						
1-1-RR-BF4	Bathroom faucet in small bathroom near kitchen; for little children	16.1	<1.0		1.7	<1.0
1-1-MAIN-CF1	Classroom faucet in main classroom	2.0	<1.0		2.5	<1.0
1-1-CON-KF1	Kitchen faucet in conference room; used for coffee	18.9	2.7	Handwash only	9.2	<1.0