



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS &amp; CHILD CARE FACILITIES

District: Community Action Agency of OKCSchool: Kiddie Village Head StartSampling Dates: 4/4/2024, 7/29/2025Status: Complete

## RESULTS

Below are the results from the first and second rounds of testing of drinking water for lead that was conducted at Community Action Agency of OKC - Kiddie Village Head Start. The initial sampling event occurred on April 4, 2024. The resampling event occurred on July 29, 2025.

In the initial sampling, eleven (11) outlets were tested resulting in a total of twenty-two (22) samples being sent to the lab.

- Twenty-one (21) samples had no detectable level of lead.
- One (1) sample had a low detection of lead between 1.0 and 14.9 µg/L.
- Zero (0) samples had a high detection of lead equal to or above 15.0 µg/L.

In the resampling, one (1) outlet was tested resulting in a total of two (2) samples being sent to the lab.

- All two (2) samples had no detectable level of lead.

The table below shows all sample results. Sample results are in micrograms per liter, shown as µg/L. For more information on how to read this report, please see our **Results Interpretation Fact Sheet**.

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
Non-Detect (<1.0 µg/L)						
1-1-KIT-IM1	Ice machine to right of kitchen on first floor; under stairs	<1.0	<1.0	N/A		
1-1-RR-BF1	Bathroom faucet in first floor boys’ restroom; in middle of hall	<1.0	<1.0	N/A		
1-1-RR-BF2	Bathroom faucet in first floor girls’ restroom; under stairs at front of building	<1.0	<1.0	N/A		
1-2-RR-BF1	Bathroom faucet in second floor boys’ restroom; in middle of hall	<1.0	<1.0	N/A		
1-2-RR-BF2	Bathroom faucet in second floor staff restroom; in office area	<1.0	<1.0	N/A		
1-2-RR-BF3	Bathroom faucet in second floor girls’ restroom; near back of stairs	<1.0	<1.0	N/A		

Sample ID	Outlet Description	First Draw (µg/L)	Flush (µg/L)	Remedial Action	First Draw (µg/L)	Flush (µg/L)
		Initial Sampling			Resampling	
1-2-RR-BF4	Bathroom faucet in second floor staff restroom; near back stairs	<1.0	<1.0	N/A		
1-3-HALL-WC1	Elkay water cooler on third floor; in middle of hall near boys' restroom	<1.0	<1.0	N/A		
1-3-RR-BF1	Bathroom faucet in third floor boys' restroom; in middle of hall	<1.0	<1.0	N/A		
1-3-RR-BF2	Bathroom faucet in third floor girls' restroom; near back stairs	<1.0	<1.0	N/A		
1-1-KIT-KF1	Kitchen faucet in three-compartment sink in kitchen	3.8	<1.0		<1.0	<1.0